

Atkins Limited
Anglo St James House
39A Southgate Street
Winchester
Hampshire SO23 9EH

Telephone +44 (0)1962 858688
Fax +44 (0)1962 810296

winchester.enquiries@atkinsglobal.com
www.atkinsglobal.com

Your Ref
LU/63/11/
Our Ref
S/AR/2011/63
Date: 10/08/2011

Planning and Development Services
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Dear Sir,


Proposal: Amendments to the previous application - Outline application for the construction of the Fitzalan Link Road between the A259 Worthing Road and the East street/Fitzalan Road roundabout - This application affects a Public Right of Way.

Site: Land between the A259 Worthing Road and East Street/Fitzalan Road Roundabout, Littlehampton, West Sussex BN17 6HN.
LU/63/11/

Thank you for your letter dated 03/08/2011.

The comments in our original response dated 04.04.2011 remain unchanged and valid for the amended details.

Yours faithfully



Senior Planning Engineer

DDTel 01962 858688
Fax 01962 810296
E mail southernwaterplanning@atkinsglobal.com

Planning and Development Services
Arun Civic Center
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your Ref
LU/63/11/
Our Ref
S/AR/2011/63
Date: 04/04/2011

Dear Sir,

Proposal: Construction of the Fitzalan Link Road between the A259 Worthing Road and the East street/Fitzalan Road Roundabout, Littlehampton, West Sussex, BN17 6HN.

Site: Land between the A259 Worthing Road and East Street/Fitzalan Road Roundabout, Littlehampton, West Sussex, BN17 6HN.
LU/63/11/

Thank you for your letter of 11/03/2011.

Please find attached a plan of the water main records showing the approximate position of a trunk main crossing the site. The exact position of the public water main must be determined on site by the applicant before the layout of the proposed development is finalised.

Please note that all existing infrastructure, including protective coatings and cathodic protection, should be protected during the course of construction works. No excavation, mounding or tree planting should be carried out within 3 metres of the public water main without consent from Southern Water.

In order to protect water supply apparatus, Southern Water requests that if consent is granted, a condition is attached to the planning permission. For example "The developer must agree with Southern Water, prior to commencement of the development, the measures to be undertaken to protect the public water supply main."

The Council's Building Control officers / technical staff or environment agency should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

For further advice, the applicant is advised to contact, *Atkins Ltd, Anglo St James House, 39A Southgate Street, Winchester, SO23 9EH* (Tel 01962 858688), or www.southernwater.co.uk.

Yours faithfully

Network Development
Atkins Ltd, for Southern Water

Tel 01962 856688
Fax 01962 810296
E mail southernwaterplanning@atkinsglobal.com