

From: Chima Umunnakwe <Chima.Umunnakwe@arun.gov.uk>

Sent: 17 May 2022 08:55

To: Planning.Responses <Planning.Responses@arun.gov.uk>

Cc: Obafemi Okusipe <Obafemi.Okusipe@arun.gov.uk>

Subject: LU/81/22/PD

Dear Planning,

I have considered the proposed application and Environmental Health has no objection in principle to the proposed scheme; however, the following matter must be considered:

Sound Insulation Scheme

Prior to the commencement of the development hereby approved, a scheme to demonstrate that the internal noise levels within the residential units will conform to the 'Indoor ambient noise levels for dwellings' guideline values specified within Table 4 under section 7.7.2 of BS 8233:2014 and shall be complied by a competent acoustician on sound insulation and noise reduction for buildings and shall be submitted to and approved in writing by the Local Planning Authority. The scheme should take into account the correct number of air changes required for noise affected rooms. The works specified in the approved scheme shall then be carried out in accordance with the approved details prior to occupation of the premises and be retained thereafter.

Reason: To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working, the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of The Adopted Arun Plan 2011 – 2031

Regards

Chima Umunnakwe
Environmental Protection Officer
Technical Services

T: 01903 737336

E: chima.umunnakwe@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk