

Arun District Council
Development Control
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Our ref: HA/2022/124096/01-L01
Your ref: LU/86/22/PL
Date: 22 April 2022

Dear Sir/Madam

DEMOLITION OF EXISTING BUILDINGS AND ERECTION OF 2 NO. BUILDINGS INCORPORATING COMMERCIAL (E) AT GROUND FLOOR WITH 4 RESIDENTIAL UNITS ABOVE.(RESUBMISSION OF LU/182/18/PL). 46A PIER ROAD, LITTLEHAMPTON, BN17 5LW.

Thank you for consulting the Environment Agency on the above application.

We have reviewed the information as submitted and set out our position below.

Environment Agency position

The proposed development will only meet the National Planning Policy Framework's requirements in relation to flood risk if the following planning condition is included. We request that the following condition be attached to any planning permission granted.

Condition

The development shall be carried out in accordance with the submitted flood risk assessment (ref FRA 4023) and the following mitigation measures it details:


- Finished floor levels shall be set no lower than 5.23 metres above Ordnance Datum (AOD)

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reason

To reduce the risk of flooding to the proposed development and future occupants

Environment Agency
Guildbourne House Chatsworth Road, Worthing, West Sussex, BN11 1LD.



Please do not hesitate to contact me using the contact details shown below should you have any queries regarding the above information.

Yours faithfully

Mrs Sophie Brown
Sustainable Places Planning Advisor

