

Environmental Health Consultation Response

To	Emma Sheppard
Date	27-08-2025
Planning Ref	LU/93/25/PL
Site Description	Buildings 5 And 6 Watersmead Business Park Worthing Road Littlehampton West Sussex BN17 6LS
Date of Application	2025-05-28 00:00:00
Category	Application
Recommendation	No Objection No Objection — with conditions Objection Holding Objection

EH Comments:

I have considered the additional statement by Sharps Redmore Dated 4th July 25, Project No 2422899 and it is clear that we do not agree on the objective elements of the noise assessment.

I also do not believe that as part of a good acoustic design, it is acceptable to cause a “potential significant adverse effect”, so I do not agree that deliveries from 05.00 Monday to Friday or from 06.00 Saturday and especially Sunday is acceptable.

I do however, concede that the results indicate that there should be low impact if the deliveries occur from 06.00 so this should not be restricted.

I would still recommend the following conditions if consent were to be granted.

Conditions Recommended:

PCCONSTR1 : Construction Management Plan

including WSCC and hours provisions

No development shall take place (or such other date or stage in development as may be agreed in writing by the Local Planning Authority) until a Construction and Environmental Management Plan (CEMP) has been submitted to and approved in writing by the Local Planning Authority, who shall consult with National Highways, WSCC Highways, the council's Environmental Health Team and Ecologist as appropriate. The approved CEMP shall thereafter be implemented and adhered to throughout the construction period. This shall require the applicant and contractors to minimise disturbance during demolition and construction. The CEMP shall provide details as appropriate, including but not necessarily restricted to, the following matters:

- the anticipated number, frequency, types and timing of vehicles used during demolition/construction (vehicles should avoid the strategic road network during the peak hours off 08:00-09:00 and 17:00-18:00 where practicable)

- the preferred road routing for all construction traffic associated with the development

- provision of wheel washing facilities (details of their operation and location) and other works required to mitigate the impact of construction upon the public highway, including the provision of Temporary Traffic Regulations Orders

- details of street sweeping

- details of suppression of dust and dirt arising from the site

- a scheme for recycling/disposing of waste resulting from works (i.e. no burning permitted)

- details of all proposed external lighting to be used during works, including location, height, type and direction of light sources and intensity of illumination

- details of areas for the unloading, loading, parking and turning of vehicles on site

- details of areas to be used for the storage of plant and materials associated with the development

- details of the temporary construction site enclosure to be used throughout the course of construction, including access gates, decorative displays and facilities for public viewing, where appropriate

- contact details for the site contractor, site foreman and CDM coordinator, including out-of-hours contact details

- details of the arrangements for public engagement/consultation prior to and during the

development

- details of any temporary traffic management that may be required to facilitate the development, including chapter 8 traffic signage**

- measures to minimise the noise and vibration generated by the construction process, to include hours of work, proposed methods of piling for foundations, the careful selection of plant and machinery and the use of noise mitigation barriers.**

If residential properties are to be completed and occupied prior to the whole development being finished, a scheme to protect those early occupants from noise and vibration shall be submitted to and approved in writing by the local planning authority.

Details of how measures will be put in place to address any environmental problems arising from any of the above shall be provided. A named person shall be appointed by the applicant to deal with complaints and shall be available on site and their availability made known to all relevant parties. No demolition/construction activities shall take place other than between 08.00 hours and 18.00 hours on Monday to Friday and between 08.00 hours and 13.00 hours on Saturday with no work on Sundays or Bank/Public Holidays.

Reason:

In the interests of the safety/amenity of nearby residents and occupiers of any nearby noise-sensitive premises, the safety and general amenities of the area and in the interests of highways safety in accordance with Arun Local Plan and the NPPF policies D DM1, QE SP1, QE DM1, QE DM2, QE DM3 and T SP1. This is required to be a pre-commencement condition because it is necessary to have the construction site set-up agreed prior to access by demolition/construction staff.

ENV5 : Unexpected contamination (precautionary condition)

If during development, any visible contaminated or odorous material (for example, asbestos containing material, stained soil, petrol/diesel/solvent odour, underground tanks or associated pipework) not previously identified is found to be present on the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified, independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unexpected contamination shall be dealt with must be submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason:

To protect the amenity of local residents in accordance with the Arun Local Plan policy QE DM4.

LIGHT01 : Lighting scheme

combined EH and Ecology

Prior to the occupation of any part of the development, full details of all new external lighting, including type of light appliance, the height and position of fitting, predicted illumination levels and light spillage, shall be submitted to and approved in writing by the Local Planning Authority. The scheme should seek to conform with the recommendations of the Institute of Lighting Professionals (ILP) 'Guidance Notes for the Reduction of Obtrusive Light' (GN01:2011) and:

a)

identify those areas/features on site that are particularly sensitive for bats and that are likely to cause disturbance in or around their breeding sites and resting places or along important routes used to access key areas of their territory, for example, for foraging

b)

show how and where external lighting will be installed through provision of appropriate lighting contour plans and technical specifications so that it can be clearly demonstrated that areas to be lit will not disturb or prevent the above species using their territory or having access to their breeding sites and resting places.

All external lighting shall be installed in accordance with the specifications and locations set out in the scheme and maintained thereafter in accordance with the scheme. Under no circumstances should any other external lighting be installed without prior written consent from the Local Planning Authority.

Reason:

In the interests of the amenities of the area, the site's biodiversity (particularly in respect of bats), the interests of minimising crime, the interests of road safety and to minimise unnecessary light spillage outside the development site in accordance with Arun Local Plan policies QE SP1, QE DM2, T SP1 and ENV DM5.

From: Daun Johnson on behalf of Planning.Responses
Sent: 28 August 2025 09:05
To: Planning Scanning
Subject: FW: Planning Response LU-93-25-PL - Buildings 5 And 6, Watersmead Business Park, Worthing Road, Littlehampton, West Sussex, BN17 6LS
Attachments: communication.pdf

Please upload attachment to LU/93/25/PL, planning, consultee response, environmental health

Daun Johnson
Technical Support Unit Assistant
Planning Services

T: 01903 737762 Ext 37762
E: Daun.Johnson@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: chris.white@arun.gov.uk <chris.white@arun.gov.uk>
Sent: 27 August 2025 20:20
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Chris White <Chris.White@arun.gov.uk>
Subject: Planning Response LU-93-25-PL - Buildings 5 And 6, Watersmead Business Park, Worthing Road, Littlehampton, West Sussex, BN17 6LS

Planning Response LU-93-25-PL - Buildings 5 And 6, Watersmead Business Park, Worthing Road, Littlehampton, West Sussex, BN17 6LS

Hi Emma,

Please find attached EH planning response for the above application..
Kind Regards

Chris White
Environmental Protection Officer, Environmental Health
Arun District Council

T: 01903 737663
E: chris.white@arun.gov.uk

Council Information:

Environmental Health, Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF

T: 01903 737500 - **E:** EHPlanningConsultations@arun.gov.uk

<http://www.arun.gov.uk>
NLPG UPRN 100062237016
DX 57406 Littlehampton
You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.