

From: Anita Gardner
Sent: 13 December 2018 17:57
To: Planning.Responses
Subject: FW: LY/16/18/DOC - Roseland, The Causeway, Arundel
Importance: High

Please scan as a consultee response

Anita Gardner | Principal Planner, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37529 | External: +44 (0) 1903 737529 | E-mail: anita.gardner@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Carol Reynolds
Sent: 23 November 2018 07:56
To: Anita Gardner
Subject: FW: LY/16/18/DOC - Roseland, The Causeway, Arundel
Importance: High

Dear Anita,

Environmental Health: I refer to the Planning Condition Indoor Noise Survey Produced by Acoustic Associates Sussex Ltd, dated 3rd September 2018, Ref J2327. The report fails to identify the location of the monitoring points (and neither is this apparent in any other part of this application). Please provide a floorplan on a site map. Further clarification is also required as to whether noise monitoring was carried out with the windows closed and the ventilation louvres either open or closed. On the basis of this report I cannot agree discharge of Condition 13 in this case as further information is required.