

From: Amanda Scholes on behalf of Planning.Responses
Sent: 01 April 2021 08:39
To: Planning Scanning
Subject: FW: Planning Consultation on: M/103/20/HH

Essential maintenance is being carried out to the planning, building control and local land charges database during the week commencing 12 April 2021.

During this time there will be no public or staff access to any records held within this database, and it will not be possible to carry out any of the following tasks via the Arun website:

- Research planning and building control history
- View any planning applications, plans, agreements, tree preservation orders or competent persons data
- Submit building control applications
- Submit planning application comments
- Report any planning compliance issues

The publicity and consultation period for all planning applications that fall over this week will be extended by a further week to ensure no one is disadvantaged.

All other aspects of planning, building control and local land charges will be limited during this week and you are strongly advised to contact the individual departments before 12 April 2021 for specific restrictions during this time.

Amanda Scholes

T: 01903 737453

E: amanda.scholes@arun.gov.uk



To register to receive notification of planning applications in your area please go to
www.arun.gov.uk/planning

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Sarah Burrow <Sarah.Burrow@arun.gov.uk>
Sent: 31 March 2021 16:42
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Zoe Toppin <Zoe.Toppin@arun.gov.uk>; Paul Cann <Paul.Cann@arun.gov.uk>
Subject: RE: Planning Consultation on: M/103/20/HH

Engineers Comments Regarding Surface Water Drainage

This application site is situated in Flood Zone 2 and 3, within an area that is susceptible to surface water flooding and in an area which has seen historic flooding. It is also within the Lidsey Treatment Catchment where surface

water drainage proposals are closely monitored to minimise any additional flows entering the foul sewer. Infiltration is highly unlikely to be viable in this location.

I have not considered the proposed floor levels for the development and how these relate to expected flood levels. Please consult the EA for their opinion on this.

If you are minded to approve the application please apply the following conditions to ensure that the development is adequately drained and does not increase flood risk elsewhere.

PCENG D2

“Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.”

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

And the accompanying informative:

INFORM D

“Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers.

Supplementary guidance notes regarding surface water drainage are located here

<https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available on Arun District Councils website, this should be submitted with a Discharge of Conditions Application.”

PCENG D3

“The development shall not proceed until details have been submitted to and approved in writing by the Local Planning Authority for any proposals: to discharge flows to watercourses; or for the culverting, diversion, infilling or obstruction of any watercourse on or adjacent to the site. Any discharge to a watercourse must be at a rate no greater than the pre-development run-off values. No construction is permitted, which will restrict current and future land owners from undertaking their riparian maintenance responsibilities in respect to any watercourse or culvert on or adjacent to the site. “

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W DM1, W DM2 and W DM3 of the Arun Local Plan. And to ensure that the duties and responsibilities, as required under the Land Drainage Act 1991, and amended by the Flood and Water Management Act 2010, can be fulfilled without additional impediment following the development completion. It is considered necessary for this to be a pre-commencement condition to protect existing watercourses prior to the construction commencing.

And the accompanying informative:

INFORMD2

"Under Section 23 of the Land Drainage Act 1991 Land Drainage Consent must be sought from the Lead Local Flood Authority (West Sussex County Council), or its agent (Arun District Council land.drainage@arun.gov.uk), prior to starting any works (temporary or permanent) that affect the flow of water in an ordinary watercourse. Such works may include culverting, channel diversion, discharge of flows, connections, headwalls and the installation of trash screens.

The development layout must take account of any existing watercourses (open or culverted) to ensure that future access for maintenance is not restricted. No development is permitted within 3m of the bank of an ordinary watercourse, or 3m of a culverted ordinary watercourse."

Kind Regards

Sarah Burrow

Engineering Assistant, Engineering Services

T: 01903 737815

E: sarah.burrow@arun.gov.uk

Current working pattern: Monday 8am-2:30pm, Tuesday 8am-5:30pm, Wednesday 8am-5pm, Thursday 8am-5:30pm, Friday 8am-11:30am.

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 23 February 2021 12:04

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Consultation on: M/103/20/HH

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

Town & Country Planning Act 1990 (as amended)

Town & Country Planning (Development Management Procedure) (England) Order 2015

Planning Permission for Works or Extension to a Dwelling

Application No: M/103/20/HH

Registered: 23rd February 2021

Site Address: Ancton Barn Ancton Lane Middleton-On-Sea PO22 6NJ

Grid Reference: 498034 100654

Description of Works: Enlargement of existing Northeast wing, alteration to barn entrances, and addition of opening and fixed glazed roof lights to the existing barn

The Council have received the above application.

[Click here to view the application details](#)

Should you have any comments to make, these should be sent by replying to this email by 25th March 2021 . You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

The application will be determined having regard to the development plan policies (if any are relevant) and other material considerations. The development plan can be accessed via the website

<https://www.arun.gov.uk/development-plan> as can the the leaflet how to respond to planning applications

<https://www.arun.gov.uk/planning-application-comments> which deals with material planning considerations.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

Should the application go to appeal the Planning Inspectorate will publish any comments made to the Council on their website: <https://www.planningportal.co.uk/info/200207/appeals> but they will protect personal details.

When the appeal relates to a householder application there will be no opportunity to make further comments.

In the absence of a reply within the period stated, I shall assume that you have no observations to make

Yours sincerely

Zac Denton

Planning Officer- Arun District Council

Telephone: 01903 737500 x37447

Email: Zac.Denton@arun.gov.uk

PLCONSULT (COB) 2020