

Sandra Edwards

From: Amanda Scholes on behalf of Planning.Responses
Sent: 07 December 2017 08:39
To: Planning Scanning
Subject: FW: Planning Consultation on M/121/17/DOC

From: Paul Cann
Sent: 06 December 2017 16:49
To: Planning.Responses
Subject: RE: Planning Consultation on M/121/17/DOC

Surface Water Drainage (Condition no.7) Comments:

1. Please provide construction details for the orifice flow control chamber & specifying the diameters of all associated incoming/outgoing pipes.
2. Provide detail for outlet arrangement where pipe exits permeable pavement into orifice control chamber ie. formpave distribution tank.
3. Where the existing gullies are being replaced with catchpit manholes – please provide construction details. Note; grated covers to be provided. This construction will also need to be agreed with WSCC.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

[Paul Cann](#) | Senior Engineer (Drainage & Coastal), Engineering Services, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 29 November 2017 09:34
To: Paul Cann
Subject: Planning Consultation on M/121/17/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: M/121/17/DOC

Registered: 16-NOV-17
Site Address: 155 Middleton Road MIDDLETON-ON-SEA PO22 6DF

Description of Works: Approval of details reserved by conditions imposed on planning reference M/75/17/PL relating to condition No.5. (materials & finishes), No.6. (Foul & surface water design), No.7 (Surface water design), No.10 (Hard & soft landscaping) & No.11 (Site set up)

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent **by replying to this email** by 13th December 2017.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
