

DECISION NOTICE

Application Ref: M/143/18/PL

1 To Addressee

Mr M Gibbens
LOOK, Design & Build
Forum House
Stirling Road
Chichester
PO19 7DN

2 Site Address

66 Ancton Way
Elmer
Middleton-On-Sea
PO22 6JP

3 Description of Development

Erection of a new 4 bedroom dwelling

4 In pursuance of their powers under this Act and related Orders and Regulations the Council **PERMIT** this development to be carried out in accordance with the application and plans and subject to the following conditions.

- 1 The development hereby permitted shall be begun before the expiration of 3 years from the date of this permission.

Reason: To comply with Section 91 of the Town and Country Planning Act 1990 (as amended).

- 2 The development hereby approved shall be carried out in accordance with the following approved plans:

PA-294-01

PA-294-02

PA-294-03

PA-294-04

PA-294-05

PA-294-06

Tree Constraints Plan LLD 1758-ARB-DWG-001 Rev 00

Tree Retention and Protection Plan LLD 1758-ARB-DWG-002 Rev 00

Reason: For the avoidance of doubt and in the interests of amenity and the environment in accordance with policy D DM1 of the Arun Local Plan.

- 3 Development shall not commence, other than works of site survey and investigation, until full details of the proposed surface water drainage scheme have been submitted to and approved in writing by the Local Planning Authority. The design should follow the hierarchy of preference for different types of surface water drainage disposal systems as set out in Approved Document H of the Building Regulations, and the recommendations of the SuDS Manual produced by CIRIA. Winter groundwater monitoring to establish highest annual ground water levels and winter Percolation testing to BRE 365, or similar approved, will be required to support the design of any Infiltration drainage. No building / No part of the extended building shall be occupied until the complete surface water drainage system serving the property has been implemented in accordance with the agreed details and the details so agreed shall be maintained in good working order in perpetuity.

Reason: To ensure that the proposed development is satisfactorily drained in accordance with policies W SP1, W DM1, W DM2 and W DM3 of the Arun Local Plan. This is required to be a pre-commencement condition because it is necessary to implement the surface water drainage system prior to commencing any building works.

- 4 The development shall be carried out in accordance with the submitted flood risk assessment (ref UK Flood Risk Consultants: Flood Risk Assessment- 66 Ancton Way, Bognor Regis PO22 6JP) and the following mitigation measures and plans it details:

All sleeping accommodation will be located on the first floor and above. These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements.

These mitigation measures shall be fully implemented prior to occupation and subsequently in accordance with the scheme's timing/phasing arrangements. The measures detailed above shall be retained and maintained thereafter throughout the lifetime of the development.

Reason: To reduce the risk of flooding to future occupants in accordance with Policy W DM2 of the Arun Local Plan.

- 5 Before the site is occupied or any machinery is introduced to the site or demolition work or construction work or alterations to existing ground levels takes place the Arboricultural Expert representing the site owner(s) must provide the local planning authority with written evidence by way of a report with attached photographs demonstrating that all protective fencing has been inspected to verify it is 'Fit for Purpose' as required under British Standard 5837:2012 and been erected and positioned exactly as shown on the Tree Retention and Protection Plan, dwg.no. LLD1758-ARB-DWG-002, Rev 00.

If there is deemed to be a need for any Utility Service Route connections to bisect retained tree Root Protection Areas/Zones, then prior to their installation a Method Statement prepared by an Arboricultural Expert must be submitted that stipulates how this can be achieved without adverse impact on tree roots. Written approval and confirmation of acceptance of this Methodology must be issued before any works are commenced out on site.

Reason: To comply with BS5837 and to ensure that retained trees are afforded due respect and appropriate levels of protection such that their ongoing health and vitality is not compromised, and they can continue to enhance the landscape and amenity of the area in accordance with Policy ENV DM4 of the Arun Local Plan.

- 6 No part of the development shall be first occupied until plans and details of visibility splays with

regards to the front access have been submitted to and approved in writing by the Local Planning Authority. Once provided the splays shall thereafter be maintained and kept free of all obstructions over a height of 0.6 metre above adjoining carriageway level or as otherwise agreed.

Reason: In the interests of road safety and in accordance with policy T SP1 of the Arun Local Plan..

- 7 No part of the development shall be first occupied until the car parking spaces have been constructed in accordance with plans and details to be submitted to and approved in writing by the Local Planning Authority. These spaces shall thereafter be retained at all times for their designated use.

Reason: To provide car-parking space for the use in accordance with policy T SP1 of the Arun Local Plan.

INFORMATIVE: Statement pursuant to Article 35 of the Town and Country Planning (Development Management Procedure)(England) Order 2015. The Local Planning Authority has acted positively and proactively in determining this application by identifying matters of concern within the application (as originally submitted) and negotiating, with the Applicant, acceptable amendments to the proposal to address those concerns. As a result, the Local Planning Authority has been able to grant planning permission for an acceptable proposal, in accordance with the presumption in favour of sustainable development, as set out within the National Planning Policy Framework.

INFORMATIVE: Sothorn Water require that the exact position of the public foul rising main must be determined on site by the applicant. This should be done prior to construction starting.

No development or tree planting should be carried out within 3 metres of the external edge of the public foul rising mains without consent from Southern Water.

No soakaways, swales, ponds, watercourses or any other surface water retaining or conveying features should be located within 5 metres of a public rising mains.

All existing infrastructure should be protected during the course of construction works.

INFORMATIVE: Infiltration rates for soakage structures are to be based on percolation tests undertaken in the winter period and at the location and depth of the proposed structures. The percolation tests must be carried out in accordance with BRE365, CIRIA R156 or a similar approved method and cater for the 1 in 10 year storm between the invert of the entry pipe to the soakaway, and the base of the structure. It must also have provision to ensure that there is capacity in the system to contain below ground level the 1 in 100 year event plus 40% on stored volumes, as an allowance for climate change. Adequate freeboard must be provided between the base of the soakaway structure and the highest recorded annual groundwater level identified in that location. Any SuDS or soakaway design must include adequate groundwater monitoring data to determine the highest winter groundwater table in support of the design. The applicant is advised to discuss the extent of groundwater monitoring with the Council's Engineers.

Supplementary guidance notes regarding surface water drainage are located here <https://www.arun.gov.uk/surfacewater> on Arun District Councils website. A surface water drainage checklist is available here <https://www.arun.gov.uk/drainagechecklist> on Arun District Councils website, this should be submitted with a Discharge of Conditions Application.

INFORMATIVE: A formal application for connection to the public sewerage system is required in order to service this development. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link:

<https://beta.southernwater.co.uk/infrastructure-charges>

Our initial investigations indicate that there are no public surface water sewers in the vicinity of the area to serve this development. Alternative means of draining surface water from this development are required. This should not involve disposal to a public foul sewer. The disposal of surface water from this development should be in compliance with the following hierarchy of Part H3 of Building Regulations:

- a) An adequate soakaway or some other adequate infiltration system.
- b) A water course.
- c) Where neither of the above is practicable: a sewer.

Due to surface water inundation issues in the Lidsey Catchment the applicant is advised to adopt, where appropriate, the measures in the table "Practical measures to reduce the potential impacts of development". Developer should look to protect the public sewerage system from inundation and infiltration, which contribute to flooding in unfavourable conditions.

For further advice, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW (Tel: 0330 303 0119), www.southernwater.co.uk or by email at developerservices@southernwater.co.uk



Neil Crowther
Group Head of Planning

Case Officer: Mr R Castro-Parker
Decision Issued: **20th September 2019**

Arun District Council
The Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex BN17 5LF

IT IS IMPORTANT THAT YOU READ THE NOTES ATTACHED TO THIS DOCUMENT

APPEALS TO THE SECRETARY OF STATE

If you are aggrieved by the decision of your local planning authority to refuse permission for the proposed development or to grant it subject to conditions, then you can appeal to the Secretary of State under section 78 of the Town and Country Planning Act 1990.

If this is a decision on a planning application relating to the same or substantially the same land and development as is already the subject of an enforcement notice, and you want to appeal against this planning application decision, then you must do so within 28 days of the date of this notice.

If an enforcement notice is served relating to the same or substantially the same land and development as in your application and you want to appeal against this planning application decision, then you must do so within 28 days of the date of service of the enforcement notice, or within 12 weeks of the date of this notice, whichever period expires earlier.

Otherwise, if you want to appeal against this decision then you must do so within 6 months of the date of this notice.

Appeals must be using a form which you can get from the Secretary of State at Temple Quay House, 2 The Square, Temple Quay, Bristol BS1 6PN (Tel: 0303 444 5000) or online at <http://acp.planninginspectorate.gov.uk>

The Secretary of State can allow a longer period for giving notice of an appeal but will not normally be prepared to use this power unless there are special circumstances which excuse the delay in giving notice of appeal.

The Secretary of State need not consider an appeal if it seems to the Secretary of State that the local planning authority could not have granted planning permission for the proposed development or could not have granted it without the conditions they imposed, having regard to the statutory requirements, to the provisions of any development order and to any directions given under a development order.

PURCHASE NOTICES

If either the local planning authority or the Secretary of State refused permission to develop land or grants it subject to conditions, the owner may claim that he can neither put the land to a reasonably beneficial use in its existing state nor render the land capable of a reasonably beneficial use by the carrying out of any development which has been or would be permitted.

In these circumstances, the owner may serve a purchase notice on the Council (that is, where the land is situated in a National Park, the National Park authority for the Park, or in any other case the district council in whose area the land is situated). This notice will require the Council to purchase the owner's interest in the land in accordance with the provisions of Chapter 1 of Part VI of the Town & Country Planning Act 1990.

Please note that this decision notice only relates to matters under the Planning Acts and does not give consent under any other legislation that may apply to the development. You will need to carry out your own checks to determine whether any other consents or permissions are required. For example, the Building Regulations are likely to apply to most developments, and a Highways Licence may be required from West Sussex County Council for any development within the public highway (including the placing of skips on highway land).