

WEST SUSSEX COUNTY COUNCIL CONSULTATION

TO:	Arun District Council FAO: Planning Officer
FROM:	WSCC – Lead Local Flood Authority
DATE:	26/07/22
LOCATION:	Land South of Grevatts Lane/A259 Climping
SUBJECT:	M/16/22/PL Laying out of an 18 hole 72 par golf course, a 9 hole golf course, practice greens and a driving range including a buggy compound; the formation of a new access onto the A259; construction of a club house with associated golf club facilities; the construction of a maintenance building and external area of hardstanding; the laying of parking, new roads and paths; new landscape planting; surface water drainage basins and water storage resevoirs; and other earth works and infrastructure. This application also lies within the parishes of Climping and Yapton, is a Departure from the Development Plan and affects a Public Right of Way. This application is subject to an Environmental Statement. From Arun DC - I am able to inform you that I have received an amendment to the above application dated 21st June 2022 relating to:- amended plans to address consultee points and slight amendment to red line plans.
RECOMMENDATION:	Advice

West Sussex County Council (WSCC), in its capacity as the Lead Local Flood Authority (LLFA), has been consulted on the above proposed development in respect of surface water drainage.

The following is the comments of the LLFA relating to surface water drainage and flood risk for the proposed development and any associated observations, recommendations, and advice.

Flood Risk Summary

Current surface water flood risk based on 30year and 100year events	High risk
Comments: Current surface water mapping shows that the proposed site is at High risk from surface water flooding. This risk is based on modelled data only and should not be taken as meaning that the site will/will not definitely flood in these events. Any existing surface water flow paths across the site should be maintained and mitigation	

measures proposed for areas at high risk.

Reason: NPPF paragraph 163 states – ‘When determining any planning application, local planning authorities should ensure flood risk is not increased elsewhere.’

Modelled groundwater flood hazard classification

Moderate to High risk

Comments:

The area of the proposed development is shown to be at Moderate to High risk from groundwater flooding based on current mapping. This risk is based on modelled data only and should not be taken as meaning that the site will/will not suffer groundwater flooding.

Ground water contamination and Source Protection Zones.

The potential for ground water contamination within a source protection zone has not been considered by the LLFA. The LPA should consult with the EA if this is considered as risk.

Watercourses nearby?

Yes

Comments:

Current Ordnance Survey mapping shows watercourses running close to/across the site.

Local or field boundary ditches, not shown on Ordnance Survey mapping, may exist around or across the site. If present these should be maintained and highlighted on future plans.

Works affecting the flow of an ordinary watercourse will require ordinary watercourse consent and an appropriate development-free buffer zone should be incorporated into the design of the development.

Records of any surface water flooding within the site?

No

Comments:

We do not have any records of historic surface water flooding within the confines of the proposed site. This should not be taken that the site itself has never suffered from flooding, only that it has never been reported to the LLFA.

Future development - Sustainable Drainage Systems (SuDS)

In the spirit of SuDS implementation, and in line with policies within the West Sussex Lead Local Flood Authority Policy for the Management of Surface Water, betterment for surface water systems on the new developments should be sought. This could include retention at source through rain gardens, permeable paving, swales or bioretention systems. SuDS landscaping significantly improves the local green infrastructure provision and biodiversity impact of the developments whilst also having surface water benefits.

This application will be subject to review by the District Council Drainage Engineer to identify site specific land use considerations that may affect surface water management and for a technical review of the drainage systems proposed.

The disposal of surface water via infiltration/soakaway should be shown to have been investigated through an appropriate assessment in consultation with the District Drainage Engineer.

All works to be undertaken in accordance with the LPA agreed detailed surface water drainage designs and calculations for the site, based on sustainable drainage principles.

The maintenance and management of the SuDS system should be set out in a site-specific maintenance manual and submitted to, and approved in writing, by the Local Planning Authority. The scheme shall subsequently be implemented in accordance with the approved designs.

Please note that Schedule 3 of the Flood and Water Management Act 2010 has not yet been implemented and WSCC does not currently expect to act as the SuDS Approval Body (SAB) in this matter.

Flood Risk Management Team