




From: Andrew Fuller [REDACTED]
Sent: 06 September 2017 13:27
To: Anita Gardner
Cc: Estella Wood; Ian Wightman
Subject: Ancton Manor M/31/17/HH

Dear Anita

Following consultations with both Ian Wightman and Green Oak Carpentry Co (the frame manufacturers), I now attach our amended drawing for the above application, 26905/02A. This is a substitute for 02.

This:

1. Changes the roof to a complete shallow pitched, slated roof of 20°.
2. Replaces the Lantern window with Conservation skylights.
3. Lighten the timber frame thicknesses slightly, in order to make the frame not too dominating externally. I await exact reduced timber sizes from Green Oak CC, and will be happy to provide these in due course.


I believe this to take into account the discussions with, and assistance from Ian.

With best wishes

Andrew

Andrew Fuller FRICS

Fuller Associates
Norton Studio
School Lane
Arundel
West Sussex
BN18 9DR



CHARTERED SURVEYORS - TOWN PLANNING - CONSERVATION SURVEYORS - TIMBER
FRAME CONSULTANTS

This electronic message contains information that may be privileged and confidential. The information is intended to be for the use of the individual(s) named above. If you are not the intended recipient, please be aware that any disclosure, copying, distribution or use of the contents is prohibited. If you have received this message in error, please delete it and notify me immediately.

