

From: Martyn White
Sent: 01 July 2019 11:19
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: M/38/19/DOC

M/38/19/DOC

The proposed materials and bonding appear to be acceptable. If the application had been submitted at the appropriate time, a lighter coloured mortar would have been considered to reflect that used within the existing flint and brick walling.

[Martyn White](#) | Principal Conservation Officer, Planning Policy, Directorate of Place, [Arun District Council](#) | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37717 | External: +44 (0) 1903 737717 | E-mail: Martyn.white@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.