

[REDACTED]

---

**From:** Raymond Cooper [REDACTED]  
**Sent:** 22 June 2022 16:15  
**To:** Paul Cann [REDACTED]  
**Cc:** Planning.Responses [REDACTED]; Anita Gardner [REDACTED]; Sarah Burrow [REDACTED]; David Cook [REDACTED]  
**Subject:** Re: M/39/22/DOC Briarfield

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Good afternoon Paul

Thanks for the email.

I have amended the design to address the original issues raised by your external consultants and their follow-up response of 21st June, by changing the soakaway sizing slightly and increasing the distance to

the prefabricated garage, adding in RPZs, adding in additional notes where required, amended the constructional details for the geocellular soakaways and submitted all the infiltration testing results (in both numerical & graphical data). These are all detailed out in my response comments to the original consultation.

Please find attached as pdfs for you to forward to your external consults for further consultation. I believe that I have addressed the issues and have improved the degree of documentation for DoC approval.

- 1) Drainage Layout design to revision 03
- 2) Constructional Details to revision 03
- 3) Calculations for Soakaway S/A#1 -- rear garden
- 4) Soil Infiltration Testing Results for Trial Pits T#1 & TP#2
- 5) Replacement Surface Water drainage Proposal checklist
- 6) My response notes

All other documents remain the same as for the original DoC application

As before If anyone needs any further information then please call me [REDACTED]  
[REDACTED]

Regards  
Ray

On Tue, 21 Jun 2022 at 09:02, Paul Cann <[REDACTED]> wrote:

Please find enclosed a further response from our consultant in respect to surface water drainage.


Hopefully, the applicant can resolve the outstanding points shortly.

Regards

**Paul Cann**

**Principal Drainage Engineer**

**Engineering Services**



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF  
[www.arun.gov.uk](http://www.arun.gov.uk)



---

Sign up to our newsletter [here](#)

