



Depth of Trial Pit (m)	1	m
Effective Depth (m) h_{75-25}	0.5	m
Plan Length	2	m
Plan Width	0.3	m

	Depth of Water (m)		
Time (mins)	Test 1	Test 2	Test 3
0	1.00	1.00	1.00
30	0.75	0.75	0.75
179	0.25	0.00	0.00
220	0.00	0.25	0.00
240	0.00	0.00	0.25
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00
0	0.00	0.00	0.00

V_{75-25}	0.300	m ³
p	4.6	m
a_{50}	2.900	m ²
t_{75-25}	12600	s
Soil Infiltration rate f	8.2E-06	m/s
Does the Trial pit drain 50% in 24 hrs	Yes	

