

From: Zac Denton

Sent: 20 November 2019 08:08

Subject: M/45/19/DOC - 7 Hadley Close, Middleton-On-Sea

Dear Mr Slade,

I have spoken with the Council's Drainage Engineer, who said the following:

"I have no objection to the applicant using porous paving as opposed to a soakaway. However, they will still need to supply a drainage layout and detail drawings, plus calculations. I am happy for the groundwater to be monitored over a 24 hour period to a depth greater than the proposed paving infiltration structure, but this must be when we expect it to peak in January/February. Similarly the shallow infiltration test will need to be completed at this time."

Please do not hesitate to contact me with any further enquiries.

Kind regards,

Zac

Zachariah Denton | Planning Officer, Planning Department, Directorate of Place, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37447 | External: +44 (0) 1903 737500 Ext: 37447 | E-mail: zac.denton@arun.gov.uk

Please note this information is given without prejudice and represents the informal view of the officer and not an official opinion of Arun District Council.

From: Chris Slade

Sent: 13 November 2019 16:41

To: Zac Denton <Zac.Denton@arun.gov.uk>

Subject: M/45/19/DOC - 7 Hadley Close, Middleton-On-Sea

Hi Zac

Regarding this scheme the client now wishes to utilise a porous surface for the driveway which will in essence simply self-drain as opposed to constructing a soakaway.

Can you please confirm that groundwater monitoring will not be required? We can however do a small soakaway test to confirm suitability of porous paving and sink a small borehole for 24 hours to see if there is any groundwater near surface level.

Thanks

Chris Slade **FIHE**
CGS Civils Ltd



Drainage Design | SuDS | Flood Risk Assessments | Highways | External Works

Richard Cobden House | Lion Street | Chichester | West Sussex | PO19 1LW

This e-mail and any attachment is intended for the named addressee(s) only, or person authorised to receive it on their behalf. The content should be treated as confidential and the recipient may not disclose this message or any attachment to anyone else without authorisation. Unauthorised use, copying or disclosure may be unlawful. If this transmission is received in error please notify the sender immediately and delete this message from your e-mail system. Any view expressed by the sender of this message or any attachment may be personal and may not represent the view held by the Company. All electronic transmissions to and from the Company are recorded and may be monitored. CGS Civils Ltd, Registered in England No. 8546902, VAT Registration No. 169950851.