

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 10 February 2022 15:39

To: Kathryn Welch <Kathryn.Welch@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 88 Ancton Way Elmer Middleton-On-Sea PO22 6JP - M/6/22/PL

Planning Application Reference: M/6/22/PL

Proposal: Demolition of existing bungalow and erection of 1 No 2-storey, 4-bedroom detached house with 3 No off road car parking spaces. This site is in CIL Zone 4 and is CIL Liable as new dwelling.

Address: 88 Ancton Way Elmer Middleton-On-Sea PO22 6JP

Dear Kathryn,

Environmental Health has no objection to the above proposal, however the following matters must be considered

Unexpected contamination

If during development, any visible contaminated or odorous material, (for example, asbestos containing material, stained soil, petrol / diesel / solvent odour, underground tanks or associated pipework) not previously identified, is found to be present at the site, no further development (unless otherwise expressly agreed in writing with the Local Planning Authority) shall be carried out until it has been fully investigated using suitably qualified independent consultant(s). The Local Planning Authority must be informed immediately of the nature and degree of the contamination present and a method statement detailing how the unsuspected contamination shall be dealt with must be prepared and submitted to the Local Planning Authority for approval in writing before being implemented.

If no such contaminated material is identified during the development, a statement to this effect must be submitted in writing to the Local Planning Authority.

Reason: To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Electric Vehicle Charging Points

I note from the document entitled 'Proposed Plans | Dwg. No. 6778 -05' (dated December 2021) [produced by Design Matrix UK Ltd.], I note the application includes the provision of 1 No. electric vehicle charging point and cabling to facilitate a future charging point. In the event that drawings are amended, at least 1 No. electric vehicle charging point shall be included with any permission granted. The type and manufacturer of charging point must appear on the government's document 'Electric Vehicle Homecharge Scheme Approved charge point model list', or demonstrate the proposed model is equivalent to approved manufacturers and models.

Reason: New petrol and diesel cars/vans will not be sold beyond 2030, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

Construction – Small Developments

The development shall be carried out in accordance with the 'Arun District Council Construction Code of Practice: For small developments in Arun', available from:

<https://www.arun.gov.uk/download.cfm?doc=docm93ljjm4n12193.pdf&ver=12201>

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Construction hours

No demolition/construction activities shall take place other than from 08:00 hours until 18:00 hours (Monday to Friday) and from 08:00 hours until 13:00 hours (Saturday) with no noisy work on Sunday or Bank/Public Holidays.

[In addition to these hours of working the Local Planning Authority may approve in writing a schedule of activities where it is necessary to conduct works outside the hours specified in this condition]

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

