

From: Amanda Scholes on behalf of Planning.Responses
Sent: 06 December 2019 09:04
To: Planning Scanning
Subject: FW: Planning Consultation on M/97/19/DOC

From: Joanne Lewis [REDACTED]
Sent: 05 December 2019 15:29
To: Planning.Responses [REDACTED]
Subject: RE: Planning Consultation on M/97/19/DOC

The demolition method statement is acceptable however I would prefer to see solid hoarding at the boundary with neighbouring residential properties in order to offer them greater protection from noise and dust from the demolition.

If a mobile crusher is to be used please note that the operator of the crusher is to notify this department prior to the commencement of crushing on site and a copy of the Permit for the crusher to be used should be forwarded to this department.

Joanne

Please note my normal working days are Wednesday, Thursday and Friday.

Joanne Lewis | Senior Environmental Health Officer, [Arun District Council](http://www.arun.gov.uk) | Location: Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [REDACTED]
Sent: 02 December 2019 14:19
To: EH Planning Consultations <[REDACTED]>
Subject: Planning Consultation on M/97/19/DOC

To: Environmental Health - Planning consultation

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: M/97/19/DOC

Registered: 26-NOV-19

Site Address: Poultry Farm 87 Yapton Road Middleton-On-Sea PO22 6DY

Description of Works: Approval of details reserved by condition imposed under ref M/45/16/PL relating to Condition No 18 - Construction Management Plan

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 16th December 2019.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
