

David Easton

From: Graham Evans
Sent: 07 October 2010 11:59
To: Planning.Responses
Subject: FW: Planning Consultation on: P/103/10/DOC at Sefter Farm
Attachments: 02_ILEGuidance.pdf

There is insufficient information provided in respect of the proposed exterior lighting installation to enable discharge of this condition. It is recommended that the exterior lighting installation is designed to meet the obtrusive light limitations of Table 1 in the attached Institution of Lighting Engineers (ILE) guidance note. An appropriate "Environmental Zone" should be specified in accordance with the guidance (zone E1 or E2 as considered appropriate for this location).

Graham Evans
 Senior Environmental Health Officer
 Arun District Council

From: Lynn Morphew
Sent: 04 October 2010 12:15
To: Graham Evans
Subject: FW: Planning Consultation on: P/103/10/DOC at Sefter Farm

C/N: 183525

From: planning.responses@arun.gov.uk
Sent: 04 October 2010 11:31
To: EH Planning Consultations
Subject: Planning Consultation on: P/103/10/DOC at Sefter Farm

To: Environmental Health - John Green

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION NO: P/103/10/DOC

Registered: 27-SEP-10
Site Address: Sefter Farm Pagham Road Pagham PO21 3PX

Description of Works: Application for approval of details reserved by conditions 2 & 3 of planning permission P/97/09

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 18th October 2010. You can also monitor the progress of this application through the Council web site:

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs S Leeson who can be contacted on telephone number [REDACTED]

Thanking you in anticipation

Planning Case Officer

Arun District Council

post_con_email
