

From: Simon Davis
Sent: 06 December 2018 09:20
To: Planning.Responses
Subject: FW: P/107/18/DOC 7 Webb Close

Further Drainage comments

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: Laura Gibbons
Sent: 06 December 2018 09:18
To: Simon Davis
Subject: RE: P/107/18/DOC 7 Webb Close

Hi Simon,

The soakaway details are fine. Can the permeable paving and driveway details be updated to include a permeable geotextile fully wrapping around the sub base, not just under it. And the pipe details for pipes 900-1200mm deep under roads and bedding for other flexible pipes need to both be updated to include a minimum of 150mm granular bed and surround (including the top). I apologise that I did not pick up on this before.

Hopefully these are minor points that can be corrected easily.

Thanks,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: Simon Davis
Sent: 28 November 2018 12:20
To: Laura Gibbons
Subject: FW: P/107/18/DOC 7 Webb Close

Please see amended details submitted in response to your objection

Kind Regards

Simon J Davis MRTPI | Principal Planning Officer, Planning Department, Directorate of Place, Arun District Council |
Location: Planning, First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37874 | External: +44 (0) 1903 737874 | E-mail: simon.davis@arun.gov.uk
Please note that I typically work from home on Thursdays when I am unreachable on my work phone

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.