



- Notes**
- This drawing is to be read in conjunction with all relevant Architects and Engineers drawings and specifications.
 - Dimensions are in millimetres unless noted otherwise.
 - Original topographic survey undertaken by Shaw Colegate. For full topographic survey information see Shaw Colegate drawing No. 10417-TP. All levels based on Ordnance Survey by GPS.
 - Existing levels shown thus:
 - Before excavation commences, the Contractor shall ascertain the depths, sizes and locations of all services to be crossed. Any conflicts in levels between new works and existing services shall be notified to the Engineer.
 - Edgings are shown thus:
—TE — Flush Face Timber Edging: See Sections
—PC — 50 x 150mm Precast Concrete Edging

7 Finishes Schedule: (See also Sections)

All formations shall be inspected and any soft or deleterious material shall be excavated and replaced with well compacted Class 6F4 / 6F5 material. The resultant formation shall be proof rolled.

CONCRETE APRON / ROADS
Construction: 200mm C40 Pavement Quality Concrete
C385 Mesh Reinforcement (60mm Cover)
1000 Gauge Polythene Membrane
250mm Type 1 Sub Base
150mm 6F4 / 6F5 capping fill
Triax Tx160 Geogrid by Tensar, or equivalent
Trimmed and compacted formation

600mm minimum Total
Anticipated formation: Soft to firm gravelly, sandy SILT, and soft to firm sandy, gravelly CLAY

Concrete Bay Joint Types:
(S) - Foundation Joint
(S) - Transition/Expansion Joint
(TS) - Tapered Slab Joint

CONCRETE BLOCK PAVED FOOTWAY
Construction: See Standard Detail STD.02.35 Type 3 over 6F4/6F5 Capping - where required

HARDSTANDING / CAR PARK
Construction: 20mm Shingle Dressing (to match existing)
Type 1 Sub Base Blinding
200mm 6F5 (coarse) Track Ballast
Terram 1000 (or equivalent) Geotextile

The general joint layout is provisional and subject to Contractor appointment and further consultation

B & M Plant Hire detail

P5 HARDSTANDING / CAR PARK CONSTRUCTION UPDATED. - PF-24-01-18
P4 DRAWING ISSUED FOR COMMENT. - PF-11-12-17
P3 MINOR REVISIONS. - PF-31-10-17
P2 ARCHITECTS COMMENTS INCORPORATED. - PF-19-10-17

REV	DESCRIPTION	CHECKED	DATE

Archibald Shaw

CLIENT
Barfoots of Botley

PROJECT
New Packhouse
Setter Farm, Pagham
Surfacing (Sheet 1 of 2)

DRAWN BY	CHECKED BY	DESIGNED BY
PF	VC	PF

SCALE @ A1	@DATE	STATUS
1:250	Oct. 2017	Preliminary

JOB NO.	DRAWING NO.	REVISION
28725	102.1	P5