

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 24 August 2021 13:43
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: P/119/21/DOC

Dear Planning,

Under paragraph (L) please could the sentence 'Construction work will only be carried out during normal working daylight hours' be removed as this contradicts the paragraph below which details the actual working hours.

Under the same paragraph (L) please could the words 'no machines will be operated' be amended to 'no noisy work will take place'

Under 'Additional Information on measures to control the emission of noise during construction' Environmental Health would note that the sentence 'Limit the time spent in noisy areas – every halving of time spent in a noisy area will reduce noise exposure by 3 dB' – whilst limiting time spent in noisy areas is clearly good practice, this relates to the workers and their noise exposure and not to local residents and their experience of the noise. The applicant may want to consider removing this sentence and inserting it into the appropriate Health & Safety Policy.

Noise Management Practices – please could examples relating to this site be provided?

Restricting Operating Hours of Noisy Procedures – please could the 4th sentence in this section be amended as the 'no machines' sentence above?

Regards

Fiona

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health



T: 01903 737674

E: fiona.fitzgerald@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

