

Simon Davis

From: [REDACTED]
Sent: 15 September 2021 17:47
To: Simon Davis
Subject: Re: P/119/21/DOC Inglenook
Attachments: CEMP condtion 5.pdf

Categories: For future upload

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Afternoon Simon,

I have attached the amended CEMP, incorporating the comments from WSCC Highways and the two sets of EHO comments.


The contractor is keen to progress some preliminary set-up works on site, such as the positioning of protective fencing etc. Are you able to provide an indication of when the CEMP condition could be discharged please? Thank you.

Best wishes,

Michael.

Michael Bish RIBA
ADM ARCHITECTS

Office - TRINITY, GOODWOOD, CHICHESTER, WEST SUSSEX, PO18 0NW, UNITED KINGDOM.



website - <http://www.admarchitects.co.uk>

On 2 Sep 2021, at 10:20, Simon Davis <Simon.Davis@arun.gov.uk> wrote:

Dear Michael,

We also have WSCC Highways comments so when revising the CMP can you also ensure that these are included:

- Schedule site deliveries outside times of peak traffic volume. This should be 08.00-09.00 am and 16.00 to 17.00.
- Ensuring that deliveries to site are kept to their allocated time slots.
- Avoid contractor parking in residential streets surrounding the site.
- All loaded vehicles leaving site must be sheeted.
- Ensure that there are designated walkways on and around site.

Thanks

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place
<image011.jpg>
T: 01903 737874
E: simon.davis@arun.gov.uk

Arun District Council, Civic Centre, Maltrovers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil
Sign up to our newsletter [here](#)<image012.jpg><image013.jpg><image014.png><image015.jpg>

From: Simon Davis
Sent: 26 August 2021 10:20
To: [REDACTED]
Subject: P/119/21/DOC Inglenook

Dear Michael,

Please see Env Health comments on the CMP. Can you revise the document accordingly please.

Kind Regards

Simon J Davis MRTPI
Principal Planning Officer
Directorate of Place
<image011.jpg>
T: 01903 737874
E: simon.davis@arun.gov.uk

Arun District Council, Civic Centre, Maltrovers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Arun is a CIL Charging Authority, for more information go to www.arun.gov.uk/cil
Sign up to our newsletter [here](#)<image019.jpg><image020.jpg><image014.png><image021.jpg>