

Simon Davis

From: [REDACTED]
Sent: 16 September 2021 11:17
To: Simon Davis
Subject: Fwd: Planning Consultation on: P/119/21/DOC - drainage issue and amended drawings attached.
Attachments: D1966-400 Private Construction Details Sht 1.pdf; D1966-103.1 RevC Proposed Drainage Sht 1.pdf
Categories: For future upload

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Good morning Simon,

As requested by the ADC drainage officer, our consultants have amended the drawings accordingly. Please find attached.

Best wishes,

Michael.

Michael Bish RIBA
ADM ARCHITECTS

Office - TRINITY, GOODWOOD, CHICHESTER, WEST SUSSEX, PO18 0NW, UNITED KINGDOM.

[REDACTED]

website - <http://www.admarchitects.co.uk>

Begin forwarded message:

From: Dan Lytton <[REDACTED]>
Subject: *****SPAM***** FW: Planning Consultation on: P/119/21/DOC
Date: 16 September 2021 at 10:52:04 BST
To: "[REDACTED]"

Hi Michael,

Apologies - I've never been asked for this before, but I've obtained the below accordingly. I've added it to the drawing and detail as requested also, please forward the attached.

Please see their required details below. Obviously, the Client will need to obtain a quote separately for this.

Product: Hydro-Brake Optimum

Product Reference Number: CTL-SHE-0077-2500-0865-2500

Dimensions W x D (mm) : 410 x 85

Sump Dimensions W x D (mm) : 170 x 310



Hydro International

+441275 337937

hydrobrake@hydro-int.com

Kind Regards,

Dan Lytton MEng
Engineer



www.bpcivils.co.uk

Bright Plan Civils, Transport Planning and Civil Engineering Consultants

Bright Plan Civils, 2 West Barn, Norton Lane, Chichester, PO20 3AF