

Environmental Health Consultation Response

To	Aishwarya Reddy
Date	20-12-2024
Planning Ref	P/123/24/HH
Site Description	109 West Front Road Pagham Bognor Regis West Sussex PO21 4TB
Date of Application	2024-12-06 00:00:00
Category	Planning Permission For Works Or Extension To A Dwelling
Recommendation	No Objection No Objection – with conditions Objection Holding Objection

EH Comments:

I have reviewed the above application, and I have concern bout the noise impact from the proposed air source heat pump depending on the unit these can be noisy and the 24 hour, on and off, use can be detrimental to the amenity of the nearby properties.

Before I can asses the impact from the proposed unit, we need to see evidence that the noise impact has been assessed in line with the existing background noise level.

Conditions Recommended:

From: Daun Johnson on behalf of Planning.Responses
Sent: 23 December 2024 08:06
To: Planning Scanning
Subject: FW: Planning Response P-123-24-HH - 109 West Front Road, Pagham, Bognor Regis, West Sussex, PO21 4TB
Attachments: communication.pdf

Daun Johnson
Technical Support Unit Assistant
Planning Services

T: 01903 737762 Ext 37762
E: Daun.Johnson@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: Daun Johnson <Daun.Johnson@arun.gov.uk> **On Behalf Of** Planning.Responses
Sent: 23 December 2024 07:56
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: Planning Response P-123-24-HH - 109 West Front Road, Pagham, Bognor Regis, West Sussex, PO21 4TB

Please upload attachment to P/123/24/HH as consultee response from EH

Daun Johnson
Technical Support Unit Assistant
Planning Services

T: 01903 737762 Ext 37762
E: Daun.Johnson@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>



From: chris.white@arun.gov.uk <chris.white@arun.gov.uk>
Sent: 20 December 2024 19:55
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Chris White <Chris.White@arun.gov.uk>
Subject: Planning Response P-123-24-HH - 109 West Front Road, Pagham, Bognor Regis, West Sussex, PO21 4TB

Planning Response P-123-24-HH - 109 West Front Road, Pagham, Bognor Regis, West Sussex, PO21 4TB

Hi Aishwarya,

Please find attached EH planning response for the above application..
Kind Regards

Chris White
Environmental Protection Officer, Environmental Health
Arun District Council

T: 01903 737663
E: chris.white@arun.gov.uk

Council Information:

Environmental Health, Arun Civic Centre, Maltravers Road,
Littlehampton, West Sussex, BN17 5LF

T: 01903 737500 - E: EHPlanningConsultations@arun.gov.uk

Important Notice: This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.