

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter **[here](#)**



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 26 November 2021 16:08

To: Maria Tomalova <Maria.Tomalova@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: 25 West Front Road Pagham PO21 4SY - P/143/21/PL

Planning Application Reference: P/143/21/PL

Proposal: Demolition of existing dwelling, erection of 1 No. replacement dwelling and detached garage/boat store.

Address: 25 West Front Road Pagham PO21 4SY

Dear Maria,

Environmental Health has no objection to the above proposal however the following matters must be considered.

Air Sourced Heat Pumps

A scheme shall be submitted for approval by the Local Planning Authority to demonstrate that the sound pressure level from the heat pump will not be greater than 42dBA at the façade of the nearest sensitive receptor. The scheme shall include technical specifications and a plan illustrating the location for the proposed heat pump and any sound mitigation measures required to achieve 42dBA at the façade of the nearest sensitive receptor.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Service

T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

