




From: Laura Gibbons <Laura.Gibbons@arun.gov.uk>
Sent: 22 March 2022 11:23
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Simon Davis <Simon.Davis@arun.gov.uk>
Subject: RE: Planning Consultation on: P/14/22/DOC

Engineers Comments Regarding Condition 2

As per our comments on P/15/22/DOC we strongly suggest that the surveyed watercourse levels are checked.


Kind regards,

Laura Gibbons

Drainage Engineer

Engineering Services

Please note that I work Tuesdays 08:00-16:00 for Arun only.



Arun District Council, Civic Centre, Maltravers Rd, Linsteadhampton, West Sussex, BN17 5LF

From: Planning.Responses <Planning.Responses@arun.gov.uk>

Sent: 11 March 2022 11:04

To: Land Drainage <Land.Drainage@arun.gov.uk>

Subject: Planning Consultation on: P/14/22/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

Application No: P/14/22/DOC

Registered: 9th February 2022

Site Address: Land adjacent to Sefter School House Sefter Road Bognor Regis PO21 3EE

Description of Works: Approval of details reserved by condition imposed under P/147/21/RES relating to conditions 2-detailed levels survey, 4-in curtilage cycle stores, 5-colour schedule of materials and finishes and 6-energy efficiency.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you wish to make any comments click on the link www.arun.gov.uk/planning and click into ?Enter Comment? or if this is not possible email your response to planning.responses@arun.gov.uk by **11th March 2022**.

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

Yours sincerely

Mr S Davis

Planning Case Officer- Arun District Council

Telephone: 01903 737874

Email: Simon.Davis@arun.gov.uk

PLCONDDC (CDB) 2020