



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
P/155/21/RES

Our ref
DSA000010500

Date
28/04/2022



Dear Sir/Madam,

Proposal: Approval of reserved matters (layout, scale, appearance and landscaping) following outline consent P/140/16/OUT for the 'local centre' parcel which comprises of retail, community and commercial uses, 20 No residential apartments and a 70-bed care home.

Site: P/155/21/RES: - Land West of Pagham Road, Pagham, PO21 4NJ.

Thank you for your letter dated 25/03/2022.


No discharge of foul sewerage from the site shall be discharged into the public system until offsite drainage works to provide sufficient capacity within foul network to cope with additional sewerage flows are complete. Southern Water is currently in process of designing and planning delivery of offsite sewerage network reinforcements. As previously advised Southern Water seeks to limit the timescales to a maximum of 24 months from a firm commitment of the development.

The Council's technical staff and the relevant authority for land drainage consent should be consulted regarding the surface water disposal.

Under current legislation, Southern Water can consider the adoption of SuDS if they are to be designed and constructed in line with the Design and Construction Guidance (water.org.uk/sewerage-sector-guidance-approved-documents/). No new soakaways, swales, ponds, watercourses, associated attenuation tanks or any other surface water retaining or conveying features should be located within 5 metres of a public or adoptable gravity sewer, rising main or water main.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670



For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing,
West Sussex, BN13 3NX [REDACTED]

Website: southernwater.co.uk or by email at: [REDACTED]

Yours faithfully,

Future Growth Planning Team
Business Channels

southernwater.co.uk/developing-building/planning-your-development

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd. Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2368670

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SZ8897NE

Scale: 1:2500

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

ARUN DISTRICT COUNCIL P/155/21/RES



Printed By: kishoku

Date: 9-12-2021

Southern Water MapGuide Browser

Requested By: