[redacted]

From: Simon Davis
Sent: 19 January 2026 17:22
To: [redacted]
Subject: P/179/25/DOC - Condition 8 of P/114/24/RES

Dear Jenni,

We have received a comment from Highways as follows:

The submitted details are noted. There are two additional crossing locations where tactile paving ought to be provided, namely at the junction between plots 11 and 23, and 32 and 38. Whilst acknowledged that tactile paving is provided at both locations, the paving shown is significantly offline for those taking a direct route over the junction; paving should therefore be provided inline across the junction as well.

Are you able to amend the submission to suit?

Kind Regards

Simon

Simon Davis MRTPI
Principal Planning Officer, Directorate of Growth
T: 01903 737874
E: simon.davis@arun.gov.uk
Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to
https://www1.arun.gov.uk/planning-application-finder


Our priorities...
Improving the wellbeing of Arun
Delivering the right homes in the right places
Supporting our environment to support us
Fulfilling Arun's economic potential
ARUN
DISTRICT COUNCIL