



from
**Southern
Water**

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Your ref
P/18/20/PL

Our ref
PLAN-032122

Date
02/04/2020



Dear Sir/Madam,

Proposal: Change of use from highway land to residential use for the development of 4 No. 3 bed terraced houses with associated parking & access. This application affects the setting of a listed building.

Site: P/18/20/PL: - Land West of Barton House, Manor Park, Pagham.

Thank you for your letter dated 04/03/2020.

Please find attached a plan of the sewer records showing the approximate position of a public sewers within the site. The exact position of the public sewers must be determined on site by the applicant before the layout of the proposed development is finalised.

Please note:

- The 150 mm diameter foul sewer require a clearance of 3 metres on either side of the gravity sewers to protect it from construction works and to allow future access for maintenance.
- No development or tree planting shall be carried out within 3 metres of the external edge of the public sewer without the consent from Southern Water.
- No soakaway, swales, ponds, watercourses or any other surface water retaining or conveying features shall be located within 5 metres of a public sewer.
- All existing infrastructure should be protected during the course of construction works.

Furthermore, it is possible that a sewer now deemed to be public could be crossing the development site. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its ownership before any further works commence on site.

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2366670

In order to protect public sewers, Southern Water requests that if consent is granted, a condition is attached to the planning permission; for example, the developer must agree with Southern Water, prior to commencement of the development, the measures to be undertaken to protect the public sewers.

Southern Water requires a formal application for a connection to the public foul sewer to be made by the applicant or developer. We request that should this application receive planning approval, the following informative is attached to the consent:

A formal application for connection to the public sewerage system is required in order to service this development. Please read our New Connections Services Charging Arrangements documents which has now been published and is available to read on our website via the following link southernwater.co.uk/infrastructure-charges

The planning application form makes reference to drainage using Sustainable Urban Drainage Systems (SUDS)

Under current legislation and guidance SUDS rely upon facilities which are not adoptable by sewerage undertakers. Therefore, the applicant will need to ensure that arrangements exist for the long-term maintenance of the SUDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system.

Thus, where a SUDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

- Specify the responsibilities of each party for the implementation of the SUDS scheme.
- Specify a timetable for implementation.
- Provide a management and maintenance plan for the lifetime of the development.

This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime.

The Council's Building Control officers or technical staff should be asked to comment on the adequacy of soakaways to dispose of surface water from the proposed development.

For further advice, please contact Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX (Tel: 0330 303 0119).

Yours faithfully,

Joff Edevane
Growth Planning Lead
Business Channels

Southern Water, Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX
southernwater.co.uk

Southern Water Services Ltd, Registered Office: Southern House, Yeoman Road, Worthing, West Sussex, BN13 3NX Registered in England No. 2368670