



To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



From: Craig Milligan <Craig.Milligan@arun.gov.uk>

Sent: 27 January 2022 15:14

To: Amber Willard <Amber.Willard@arun.gov.uk>; Planning.Responses <Planning.Responses@arun.gov.uk>

Subject: The Pagham Club 2 West Front Road Pagham PO21 4SY - P/2/22/DOC

Planning Application reference: P/2/22/DOC

Proposal: Approval of details reserved by condition imposed under P/10/20/PL relating to conditions 3-internal noise levels, 6-covered & secure cycle parking; 7-electric vehicle charging & 8-storage of waste

Location: The Pagham Club 2 West Front Road Pagham PO21 4SY

Dear Amber,

Condition 3 – Internal Noise Levels

Having reviewed the document entitled 'Acoustic Testing Report For Carly Barnes, 2 West Front Road, Pagham, Bognor Regis, West Sussex, PO21 4SY' (dated 12th November 2021) [produced by Airtight Noisecheck Limited] I find the report to be reliable and conclusions to verify that internal noise levels detailed in BS8233:2014 have been met. I therefore recommend the condition can be discharged.

Condition 7 – Electric Vehicle Charging

No details have been submitted in relation to electric vehicle charging points, therefore Environmental Health is unable to recommend discharge of condition at this time.

Sincerely, Craig

Craig Milligan

Environmental Health Officer, Technical Services



T: 01903 737670

E: craig.milligan@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)

Business Support during Coronavirus click [here](#)

