

Mr S Davis
Planning and Building Control
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

**Lead Local Flood Authority
Ground Floor
Northleigh
County Hall
Chichester
West Sussex
PO19 1RH**

Date 13 April 2026

Planning Reference: **P/30/26/OUT**

Site Address: **Land North of Summer Lane Pagham**

Planning Description: **Outline application with some matters reserved, except access, for up to 120 No residential dwellings including means of access into the site (not internal roads). This application is a Departure from the Development and affects a Public Right of Way.**

Dear Mr S Davis,

Thank you for your consultation on the above site. For this consultation, we have reviewed the following documents submitted:

- Report: Flood Risk Assessment, prepared by GTA Civils & Transport, dated 29 January 2026, Ref: 13226A, Third Issue
- Report: Flood Risk Sequential Test, prepared by Ridge, dated December 2025, Ref: 5027944, Rev: 1.1

The risk from surface water flooding is low but there is a known risk from rivers or coastal as part of the site is located with Flood Zone 2 and 3. All built development will be located outside of these flood risk areas and the LLFA is not concerned with the risk to the proposed dwellings from surface water. We would advise that you as Local Planning Authority, ensure that this application passes the sequential test in relation to the risk from rivers or coastal flooding.

The applicant has provided an appropriate Flood Risk Assessment (FRA) and Drainage Strategy to account for the local flood risk issues and surface water drainage at this location. Following a review of the submitted documents, the details are in accordance with NPPF and local planning policies of Arun District Council.

The information provided is suitable for an Outline planning application and the FRA and Drainage Strategy have shown that a viable surface water drainage scheme is available at the site. Infiltration will not be viable due to the high groundwater levels and therefore surface water will be discharged at an appropriate rate to the

neighbouring watercourse. The groundwater levels shall be considered in the detailed design of the drainage strategy.

Therefore, we have **no objection subject to conditions being attached to any consent** if this application is approved, and the Applicant is in agreement with pre-commencement conditions. We suggest the following wording. If the following conditions are not included, the development would be contrary to NPPF and local planning policies of Arun District Council and we would **object** until such time that the details below are submitted for review.

Condition 1:

Prior to commencement of the development, detailed designs of a surface water drainage scheme shall be submitted to and agreed with the Local Planning Authority. This shall be in accordance with the approved Flood Risk Assessment, prepared by GTA Civils & Transport, dated 29 January 2026, Ref: 13226A, Third Issue. The design shall follow the NPPF, PPG Flood risk and coastal change and National Standards for SuDS. The submitted details shall include:

1. Surface water runoff rates will be attenuated to 3l/s/ha based on the proposed impermeable area, as stated within Chapter 5.7 and 7.5 of the FRA.
2. Evidence that the surface water drainage system complies with the National Standards for SuDS for the management of everyday rainfall (interception).
3. Details of all existing and proposed watercourses and sewers, including any proposed discharge points.
4. Provision of surface water attenuation storage, sized and designed to accommodate the volume of water generated in all rainfall events up to and including the critical storm duration for the 3.33% and 1% annual probability rainfall events (both including allowances for climate change). Hydraulic calculations and detailed construction drawings shall be submitted to demonstrate this.
5. Detailed drainage layout plan, which corresponds with the hydraulic calculations.
6. An exceedance flow routing plan demonstrating no increase in surface water flood risk off site. The plan must include proposed levels and flow directions.
7. Evidence that the surface water drainage system meets Standard 4-6 of the National Standards for SuDS.
8. Construction method statement for the surface water drainage system and any ordinary watercourses within or adjacent to the site.
9. Site-specific maintenance and management plan for all elements of the surface water drainage system and any ordinary watercourses/culverts within the development.
10. Finished ground floor levels of residential properties are a minimum of 300mm above expected flood levels of all sources of flooding (including the ordinary watercourses, SuDS features and within any proposed drainage

scheme) or 150mm above ground level, whichever is the more precautionary.

Reason: To prevent flooding in accordance with National Planning Policy Framework paragraphs 181,182 and 187 plus National SuDS Standards 1 to 7, by ensuring the satisfactory management of local sources of flooding surface water flow paths, storage and disposal of surface water from the site in a range of rainfall events and ensuring the SuDS proposed operates as designed for the lifetime of the development.

Condition 2:

Upon completion of the surface water drainage scheme (or phase) and prior to the first occupation of the development (or phase), a detailed verification report, (appended with substantiating evidence demonstrating the approved construction details and specifications have been implemented in accordance with the surface water drainage scheme), has been submitted to and approved (in writing) by the Local Planning Authority. The survey and report shall demonstrate that the surface water drainage system has been constructed in accordance with the details approved and shall include as a minimum.

1. CCTV survey of underground structures,
2. A full set of “as built” drawings highlighting any minor changes to the approved drawings.
3. Demonstration that vegetation has become established.
4. Photographs of excavations (including soil profiles/horizons) and any installation of any surface water drainage structures and control mechanisms.
5. Where necessary, details of corrective works to be carried out along with a timetable for their completion, shall be included for approval in writing by the Local Planning Authority. Any corrective works required shall be carried out in accordance with the approved timetable and subsequently re-surveyed with the findings submitted to and approved in writing by the Local Planning Authority.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Local Plan Policies of Arun District Council.

Condition 3:

The development hereby approved shall not be occupied until details of the maintenance and management of the Sustainable Drainage Scheme (SuDS) in accordance with National SuDS Standard 7 have been submitted to and approved in writing by the Local Planning Authority. The drainage scheme shall be implemented prior to the first occupation of the development hereby approved and thereafter managed and maintained in accordance with the approved details in perpetuity. The Local Planning Authority shall be granted access to inspect the sustainable drainage scheme for the lifetime of the development. The details of the network in addition to those listed in SuDS Standard 7 to be submitted for approval shall include:

1. A timetable for its implementation.
2. Details of SuDS feature and connecting drainage structures and maintenance requirement for each aspect including a non-technical labelled drawing showing where they are located and how to access them.
3. A management and maintenance plan for the lifetime of the development which shall include the arrangements for adoption by any public body or statutory undertaker, or any other arrangements to secure the operation of the sustainable drainage scheme throughout its lifetime. This will include the name and contact details of any appointed management company.

Reason: To ensure that the development achieves a high standard of sustainability and ensure the flood risk is adequately addressed for each new dwelling and not increased in accordance with NPPF and Local Plan Policies of Arun District Council.

Informative:

Erection of flow control structures or any culverting of an ordinary watercourse requires consent from the appropriate authority, which in this instance is <West Sussex Lead Local Flood Authority. It is advised to discuss proposals for any works at an early stage of proposals. Further details can be found here: [Ordinary watercourse land drainage consent - West Sussex County Council](#)

Yours sincerely,

Flood Risk Management Team

[Redacted]

From: Elaine Walby on behalf of Planning.Responses
Sent: 14 April 2026 16:45
To: Planning Scanning
Subject: FW: Response to P/30/26/OUT
Attachments: P-30-26-OUT - Land North of Summer Lane v1.0.pdf

PL- Consultation- WSCC Flood Risk response

Elaine Walby
Technical Support Assistant
Planning Services

T: 01903 737 904
E: elaine.walby@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd
Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

To register to receive notification of planning applications in your area please go to <https://www1.arun.gov.uk/planning-application-finder>

Our priorities...




Improving the wellbeing of Arun



Delivering the right homes in the right places



Supporting our environment to support us



Fulfilling Arun's economic potential



Our core foundations



Connect with us: [Facebook](#) | [X](#) | [Instagram](#)

From: [Redacted]
Sent: 14 April 2026 12:33
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: Response to P/30/26/OUT

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Please could the attached response be distributed to the relevant case officer.

Regards

Flood Risk Management

Please do not reply directly to this email.

Any formal reconsultation on the application should be directed to [Redacted] but the responding officer can be contacted directly via email if there are any questions relating to this response.

LEGAL DISCLAIMER
This email and any attachments are confidential and intended solely for the persons addressed. If it has come to you in error please reply to advise us but you should not read it, copy it, show it to anyone else nor make any other use of its content. West Sussex County Council takes steps to ensure emails and attachments are virus-free but you should carry out your own checks before opening any attachment.