

1. All dimensions are in metres unless stated otherwise.
2. Do not scale from this drawing. Only written dimensions are to be used.
3. This drawing should be read in conjunction with the Architect's and Structural Engineer's design drawings and specification.
4. Where cover to pipes is less than 1.2m concrete bed and surround should be used. Where pipes with flexible joints are used the concrete protection shall be interrupted across its full cross-section with a compressible filler.
5. Refer to geotechnical report for sulphate resisting class and ACEC class.
6. All construction associated with the Foul Water Pumping Station and Foul Water Rising Main to be in accordance with Sewers for Adoption - 6th Edition & Interim Addendum and the specific requirements of Southern Water.
7. This drawing should be read in conjunction with other Foul Water Sewer Longitudinal Sections (DSM/E4761/001 to 203), Surface Water Sewer Longitudinal Sections (DSM/E4761/220 to 221), S104 Adoption Layout (DSM/E4761/402), S104 Construction Details (DSM/E4679/410 to 411), Foul Water Sewer Manhole Schedules (DSM/E4761/412), Surface Water Sewer Manhole Schedules (DSM/E4761/415 to 416) and Domestic Drainage Layouts (DSM/E4679/451 to 455).
8. ***ANY VARIANCE OR DISCREPANCY MUST BE REPORTED BACK TO RCP ENGINEERING BEFORE WORK BEGINS.***



SCALE BAR 1:500 at A1

CDM NOTES

1. EXISTING SERVICES. Depth of existing services must be determined prior to works commencing. The contractor is responsible for establishing underground services in accordance with HSE Guidance note HS (G) 47. Any services which would be within the proposed construction layers must be lowered to below the sub-base.

[illegible]

Client:-

DREW SMITH LIMITED

Site:-
SUMMER LANE
PAGHAM

Drawing Title:-
FOUL WATER RISING
MAIN LONGITUDINAL
SECTION

Date:	February 2020	Scales:	H=1:500, V=1:100 at A1
Drawn:	AC	Checked:	LAD
		Approved:	TRS

Drawing No.

DSM/E4761/230

INITIAL TENDER ISSUE

SUBJECT TO ADOPTING AUTHORITY APPROVAL



Rogers Cory Partnership
Architectural and Civil Consultants
The Old School Old School Road
Hook Hampshire RG27 9NI

T: 01256 769269 E: mail@rcpconsultants.co.uk W: rcpconsultants.co.uk