

From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 25 June 2020 19:00
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: Raymond Cole <Raymond.Cole@arun.gov.uk>
Subject: P/40/20/DOC

Dear Planning,

With respect to condition 33 (electric vehicle charging points), the condition is worded:

“Prior to the commencement of development, an Electric Vehicle Charging Strategy will be prepared and submitted to the Local Planning Authority which identifies the nature, form and location of electric charging infrastructure to be provided across the development. The electric vehicle strategy shall then be implemented in accordance with the approved details.”

Please could you ask the applicant to provide further details in relation to the nature and form of the infrastructure. In particular, please could you ask the applicant to confirm that the points will be active, and that there is an active electric vehicle charging point for all new dwellings with a driveway **or** a garage and for 20% of parking spaces for other developments. At the present time, Environmental Health is not happy for this condition to be discharged.

Environmental Health's response to the DOC for condition 32 (noise) will follow tomorrow.

Thank you

Regards

Fiona

Fiona Fitzgerald | Senior Environmental Health Officer, Environmental Health, Arun District Council | Location: Third Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF
Internal: 37674 | External: +44(0)1903 737674 | E-mail: fiona.fitzgerald@arun.gov.uk



Save the environment - think before you print.



Visit Arun's web site at www.arun.gov.uk