

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

To register to receive notification of planning applications in your area please go to
<https://www1.arun.gov.uk/planning-application-finder>

Sign up to our newsletter [here](#)



From: Fiona Fitzgerald <Fiona.Fitzgerald@arun.gov.uk>
Sent: 31 March 2022 10:38
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Cc: David Easton <David.Easton@arun.gov.uk>
Subject: P/42/22/DOC

Dear David,

Condition 15 – lighting

Please could the applicant confirm that the lighting strategy conforms with ILP Guidance Zone E3?

Condition 15 – CMP

Environmental Health is happy for this condition to be discharged.

Condition 33 – Electric Vehicle Charging Strategy

Please could the applicant confirm that 100% of houses with a driveway or garage have an active EV Charging point, and that at least 30% of all other developments have an active EV Charging point?

Regards

Fiona Fitzgerald
Senior Environmental Health Officer
Environmental Health

T: 01903 737674
E: fiona.fitzgerald@arun.gov.uk



Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)



