

[REDACTED]

[REDACTED]

From: Paul Cann
Sent: 18 September 2017 13:49
To: Simon Davis

[REDACTED]
Subject: RE: P/49/17/DOC Church Farm Holiday Village [NLP-DMS.FID263510]

Hi Simon

Further comments;

1. They need confirmation from the permavoid crate manufacturer (polypipe) that there will be no detriment to the crates due to the vehicle loadings/minimal cover.
2. The proposed headwall structures must not encroach into the profile of the ditch ie. beyond the existing banks. Add a suitable note to the drawings.

As you are on leave, I have copied in Alfred.

Regards

Paul Cann
Senior Engineer (Drainage & Coastal)

Paul Cann | Senior Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37819 | External: +44 (0) 1903 737819 | Fax: +44 (0) 1903 716019 | E-mail: Paul.Cann@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.