

Julia Mills

From: [REDACTED]
Sent: 22 September 2017 10:55
To: Stephen Morgan
Subject: FW: Church Farm Permavoid
Attachments: EPG Church Farm Permavoid Structural Calcs.pdf; Permavoid Technical Bulletin Issue 2 - Sub-Base Replacement System.pdf

Steve,

Please see the below email from Permavoid regarding the cover depth.

I will forward on the updated drawings with a note regarding the headwalls in a separate email.

Regards,
Andy

Andy Woolley
Intermediate Engineer

[REDACTED]

Nijhuis Industries UK & Ireland : [REDACTED]
Main Office: [REDACTED]

Truro Office : Nanjerrick Court, Allet : Truro, Cornwall : TR4 9DJ : United Kingdom
Bristol Office : Unit 16, Avonbank Industrial Centre : Avonmouth, Bristol : BS11 9DE : United Kingdom

SOLID SOLUTIONS IN A FLUID WORLD



Registered Office: Chy Nyverow, Newham Road, Truro, Cornwall, TR1 2DP. Registered in England & Wales No. 4785670.

The information in this e-mail is for the named addressee only. The e-mail contains privileged and confidential information and if you are not the addressee, you must not copy, distribute or take any action in reliance on it. If you receive this e-mail in error, please delete it and notify us immediately on +44 (0)333 7000 007. The contents of any attachment may contain viruses which could damage your computer. Whilst Nijhuis H2OK have taken reasonable precautions to minimise the risk of software viruses, we cannot accept any liability for any damage or loss, which you may suffer as a result of such viruses. We strongly recommend that you carry out your own virus checks before opening any attachment.

From: Joe Anderson [REDACTED]
Sent: 21 September 2017 14:48
To: Andy Woolley <[REDACTED]>
Cc: Sean Robinson <[REDACTED]>
Subject: RE: Church Farm Permavoid

Afternoon Andy,

I can confirm that we are happy with the 260mm of cover above the crates in this application which allows for 16T occasional HGV overrun.

We have run the calculations (attached) to prove this and I have also added our Technical Bulletin which shows this too.

If there are any queries, please feel free to pass my details on.


Best regards,

Joe Anderson

WMS Project Specification Specialist



Polypipe Civils
Chamwood Business Park, North Road, Loughborough, LE11 1LE



Please consider the environment before printing this e-mail.