

Planning and Development Services
Arun District Council
Arun Civic Centre
Maltravers Road
Littlehampton
West Sussex
BN17 5LF

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

[REDACTED]
[REDACTED]
Your Ref

P/140/16/OUT

Our Ref

PLAN-019330

Date

23/08/2017

Dear Sirs,

Proposal: Outline application for access only - mixed use development comprising of up to 400 dwellings, a care home with up to 70 beds, a Local Centre comprising up to 2000sqm of A1/A2/A3/D1/sui generis floorspace, provision of land for a 1FE primary school (with sufficient space to ensure that it is expandable to 2FE), provision of land for a scout hut, safeguarding of land to help link the site to the Pagham Harbour Cycle Route & other community uses including public open space & allotments with some matters reserved. This application is a Departure from the Development Plan
Site: Land South of Summer Lane & West of Pagham Road Pagham PO21 4NJ.
P/140/16/OUT

Thank you for your letter of 25/07/2017.


Further to our response sent out on 23/08/2017 regarding the above planning application consultation and additional assessment of treatment capacity, Southern Water can confirm the proposed development (400 dwellings) can be accommodated at the PAGHAM Wastewater Treatment Works (WWTW).

Please note that this would be within the vicinity of the WWTW at a point to be agreed with Southern Water Services. This would likely be at last viable point outside the WWTW (not crossing or entering the WWTW land).

Approval for a final connection to the public sewers can be obtained under Section 106 of the Water Industry Act.

Southern Water Sparrowgrove House Otterbourne Winchester Hampshire SO21 2SW www.southernwater.co.uk

Southern Water Services Ltd Registered Office: Southern House Yeoman Road Worthing BN13 3NX Registered in England No.2366670



Southern Water requires a formal application for a connection to the public sewer to be made by the applicant or developer.

A formal application for connection to the public sewerage system is required in order to service this development, please contact Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW [REDACTED] Please read through our New Connections Services Charging Arrangements documents which has now been published and is available to read through on our website via the following link [REDACTED]

Please find attached a plan of the sewer records showing the approximate position of a public sewer crossing of the site. The exact position of the public sewer must be determined on site by the applicant before the layout of the proposed development is finalised.

Please note:

No development or new tree planting should be located within 3 metres either side of the external edge of the public sewer.

No new soakaways should be located within 5 metres of a public sewer.

All other existing infrastructure should be protected during the course of construction works.

Please note there is a deed of easement of grant within the site.

Furthermore, due to changes in legislation that came in to force on 1st October 2011 regarding the future ownership of sewers it is possible that a sewer now deemed to be public could be crossing the above property. Therefore, should any sewer be found during construction works, an investigation of the sewer will be required to ascertain its condition, the number of properties served, and potential means of access before any further works commence on site.

Please note there is a deed of easement of grant within the site.

The planning application form makes reference to drainage using Sustainable Urban Drainage Systems (SUDS).

Under current legislation and guidance SUDS rely upon facilities which are not adoptable by sewerage undertakers. Therefore, the applicant will need to ensure that arrangements exist for the long term maintenance of the SUDS facilities. It is critical that the effectiveness of these systems is maintained in perpetuity. Good management will avoid flooding from the proposed surface water system, which may result in the inundation of the foul sewerage system. Thus, where a SUDS scheme is to be implemented, the drainage details submitted to the Local Planning Authority should:

Specify the responsibilities of each party for the implementation of the SUDS scheme
Specify a timetable for implementation



Provide a management and maintenance plan for the lifetime of the development. This should include the arrangements for adoption by any public authority or statutory undertaker and any other arrangements to secure the operation of the scheme throughout its lifetime.

The application details for this development indicate that the proposed means of surface water drainage for the site is via a watercourse. The Council's technical staff and the relevant authority for land drainage consent should comment on the adequacy of the proposals to discharge surface water to the local watercourse.

Any works within highway/ access road will require to protect public apparatus and the protection details need to be submitted to, and approved by Southern Water under NRSWA enquiry.

Land uses such as general hardstanding that may be subject to oil/petrol spillages should be drained by means of oil trap gullies or petrol/oil interceptors.

We request that should this application receive planning approval, the following condition is attached to the consent: "Construction of the development shall not commence until details of the proposed means of foul and surface water sewerage disposal have been submitted to, and approved in writing by, the Local Planning Authority in consultation with Southern Water."

The applicant is advised to discuss the matter further with Southern Water, Sparrowgrove House, Sparrowgrove, Otterbourne, Hampshire SO21 2SW [REDACTED].

Yours sincerely,

[REDACTED]

Luis Silva
Developer Services

SOUTHERN WATER



The positions of pipes shown on this plan are believed to be correct, but Southern Water Services Ltd accept no responsibility in the event of inaccuracy. The actual positions should be determined on site.

Based upon Ordnance Survey Digital Data with the permission of the controller of H.M.S.O. Crown Copyright Reserved Licence No. WU 298530

O.S. REF: SZ8898SE

Scale: 1:4954

Screen Print

WARNING: BAC pipes are constructed of Bonded Asbestos Cement

WARNING: Unknown (UNK) materials may include Bonded Asbestos Cement

ARUN DISTRICT COUNCIL P/532/16/OUT



Printed By: Ponnannv

Date: 3-2-2017

Southern Water MapGuide Browser

Requested By: