

From: Laura Gibbons
Sent: 13 June 2018 09:27
To: Planning.Responses
Subject: RE: Planning Consultation on P/60/18/DOC

Comments relating to Condition 14- Watercourse

Recommend that this condition is discharged based on the provided details.

Comments relating to Condition 16- drainage and pollution

The Environment Agency will need to be consulted on this.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF
Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk
Arun is Working in Partnership with Chichester District Council
Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 11 June 2018 09:18
To: Land Drainage
Subject: Planning Consultation on P/60/18/DOC

To: Engineers (Drainage)

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION P/60/18/DOC
NO:

Registered: 17-MAY-18

Site Address: Sefter Farm Pagham Road Pagham PO21 3PX

Description of Approval of details reserved by condition imposed on planning

Works: permission P/76/16/PL relating to conditions 14 (watercourse)
& 16 (drainage & pollution)

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 25th June 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mr S Davis who can be contacted on telephone number 01903 737874.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
