CIARAN KERRIGAN 29-03-2022

This design is across multiple drawings for details please refer to all drawings.

Excavation Carried Out by BUUK

The trenches highlighted in blue will be excavated and reinstated by BUUK contractors, the excavation and reinstatement of the other trenches will be the responsibility of the customer.

	Proposed	Laid
Traditional Fibre Ducts (Inside Diameter)		
4x 90mm - 350mm depth		
3x 90mm - 350mm depth		
2x 90mm - 350mm depth		
1x 90mm - 350mm depth		
Direct Lay Fibre Ducts (Inside Diameter)		
3x 55mm - 600mm depth		
2x 55mm - 600mm depth		
1x 55mm - 600mm depth		
50mm Lead in duct - 350mm depth		
Direct Lay Extractable Fibre Ducts		
24x 2fibre - 600mm depth		
12x 2fibre - 600mm depth		
General		
Backhaul Ducting		
Cable Tray		
Excavated by BUUK		
Asset Boundary		Swept-t
Chambers (Internal Dimensions)		
FW-2 Chamber - 725mm x 225mm		
FW-4 Chamber - 915mm x 445mm		
FW-6 Chamber - 1310mm x 610mm		
FW-10 Chamber - 2320mm x 740mm		
CW12 Reinforced Chamber 1220mm x 675mm		
Backhaul FW-4 Chamber - 915mm x 445mm		
Backhaul FW-6 Chamber - 1310mm x 610mm		

OSCP Types (Not to Scale)

Brick Built

Brick Built Combined

Rear / Front — Onsite 224 Cabinet With FIRS

Rear / Front — Onsite 224 Cabinet

BACK / FRONT — Link Cabinet

OSCP Awaiting Position — Awaiting Position

FIRS Mast On Structure

FIRS Mast Standalone

Fibres		
1	2	3
Blue I	Orange I	Green I
4	5	6
Red I	Grey I	Yellow I
7	8	9
Brown I	Violet I	Black I
10	11	12
White I	Pink I	Turquoise I
13	14	15
Blue II	Orange II	Green II
16	17	18
Red II	Grey II	Yellow II
19	20	21
Brown II	Violet II	Black II
22	23	24
White II	Pink II	Turquoise II

Plan Notes

This plan shows apparatus owned by the BUUK Group. Any third party apparatus indicated on these drawings is shown for indicative purposes only. The information shown on this plan is given without warranty, the accuracy cannot be guarenteed. No liability of any kind whatsoever is accepted by the company. Safe digging practices, in accordance with HS(G)47, must be used to verify and establish the actual position of apparatus. This plan is reproduced by the permission of Ordnance Survey on behalf of HMSO. © Crown copyright and database right 2007. All rights reserved Ordnance Survey Licence number 0100021063.

Developers Responsibility

When apparatus have been laid it becomes the responsibility of the developer to ensure it is suitably protected, therefire backfilling should be carried out as soon as possible. Replacement and repair of damaged apparatus, including administrative costs will be fully recharged to the developer. It will be the developer's responsibilityto recover the costs from the third parties.

Revision Notes

For a revision history of this network design please see seperate revision history document.

Open Fibre Networks

Last Edit By:	
Last Approved By:	

Unapproved Variation

OS Ref: 490076,99564

Location: Sefter Road, BOGNOR REGIS, West Sussex, PO21 3EE

Developer/Client: TDS - Technical and Development Services Ltd

Drawing Number/Title: FN0022906-1_1_of_3_Entire_site_appendix

Network Number:	Project Number:	
N0022906	N0022906-1	
Scale: 1:750	Sheet Size: A0	Revision: -