

Amanda Scholes

FX

**From:** Julie Grieves on behalf of Planning Responses  
**Sent:** 01 December 2011 08:44  
**To:** Amanda Scholes  
**Subject:** FW: Application ref: P/87/11 - 52 East Front Road, Pagham  
**Attachments:** copy letter.doc

ACK

Julie Grieves | Technical Support Unit Assistant, Planning and Building Control, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF  
 Internal: 37448 | External: +44 (0) 1903 737711 | E-mail: [julie.grieves@arun.gov.uk](mailto:julie.grieves@arun.gov.uk)

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.

**From:** Peter Cleveland  
**Sent:** 01 December 2011 08:41  
**To:** Planning Responses  
**Subject:** FW: Application ref: P/87/11 - 52 East Front Road, Pagham

Could the attached please be acknowledged as a letter of rep. ref. P/87/11.

Thanks  
 Peter

Peter Cleveland BSc MSc | Senior Planner, Planning Department, Arun District Council | Location: 1st Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF  
 Internal: 37631 | External: +44 (0) 1903 737631 | E-mail: [Peter.Cleveland@arun.gov.uk](mailto:Peter.Cleveland@arun.gov.uk)

Visit Arun's web site at [www.arun.gov.uk](http://www.arun.gov.uk)



Save the environment - think before you print.

**From:** Carolyn Nysingh **On Behalf Of** Planning  
**Sent:** 30 November 2011 12:10  
**To:** Peter Cleveland  
**Subject:** FW: Application ref: P/87/11 - 52 East Front Road, Pagham

**From:** Pagham Beach (Holdings) Ltd [<mailto:paghambeach@tiscali.co.uk>]  
**Sent:** 30 November 2011 11:37  
**To:** Planning  
**Subject:** Application ref: P/87/11 - 52 East Front Road, Pagham

FAO: P. Cleveland, Esq.,

Dear Mr. Cleveland,

I refer to my letter of 21st November regarding the above Application. I regret that my letter contains an error which I have corrected and attach a copy of my amended letter and would be grateful if this could be substituted for the original. I apologise for any inconvenience caused by this error.

May I also respectfully request that in view of the location of the Application site, having frontage to a vulnerable and exposed section of the beach foreshore, that the Application proposal is referred to the District Council's Principal Engineer (Coastal), Roger Spencer, as from experience I and adjoining residents are concerned that the Application proposal constitutes built development across the entire beach frontage of the Application site. This un-neighbourly development will remove the current facility for any over-topping in storm conditions to flow down the sides of the existing building, within the curtilage. The current Application proposal removes that facility and

01/12/2011

therefore places adjoining buildings on the beach frontage at risk, which is totally unacceptable.

Should you require further information on this matter, do please contact me.

Regards

Tony Higham

J.A. Higham MRICS  
Secretary

---

**Pagham Beach (Holdings) Ltd**

Registered in England No. 630261

Registered office:

Woodlands Cottage, Normandy, Guildford, Surrey. GU3 2HT



# Pagham Beach (Holdings) Ltd

Woodlands Cottage  
Normandy  
Guildford  
Surrey

Our Ref: JAH/SH

21<sup>st</sup> November 2011

Director of Planning Services & Housing Strategy,  
Arun District Council,  
Arun Civic Centre,  
Maltravers Road,  
Littlehampton, Sussex.  
BN17 5LF

Dear Sir,

**re. Town & Country Planning Act 1990**  
**Application ref: P/87/11**  
**52 East Front Road, Pagham**  
**Proposed extension to existing dwelling**  
**Re-submission following Application P/47/11**  
-----

I refer to the above Detail Planning application, which I have viewed on the District Council's website and as owner of adjoining land, would make the following comments:

## **Location**

-----

The application site is situated within a location designated as an Area of Special Character, but unfortunately completely disregards the Policies defined within the Local Plan for the Special Character of the Pagham Beach Estate. The application is therefore contrary to Policy GEN7 and Area 1 of the Arun District Local Plan.

The description of the location within the Design & Access Statement Revised Scheme submitted with the Application is misleading. To the south of the Application site it adjoins the beach foreshore, which is designated as part of Pagham Harbour Site of Special Scientific Interest. The land to the north of East Front Road is an extension to Bognor Reef and is part of an area of dune systems with interesting flora, including specially protected species listed in Section 8 of the Wildlife & Countryside Act. This land to the north is designated as part of Bognor Reef Site of Special Scientific Interest.

The Application site is therefore in an environmentally sensitive location and any development proposed should have regard to this.

## **Two-storey construction**

-----

Despite amendment the proposed extension to the north of the original building remains a two-storey structure of basement and elevated ground floor accommodation, and proposes a structure of considerable bulk which it is hoped the Planning Authority would consider unacceptable within the street scene. The two-storey construction is also contrary to Local Plan Policies for the Beach Estate, and if Approved will create an unwelcome precedent.

The formation of a basement with a finished floor level as defined, proposed at 2.74 OAD is over 3.000 (10'0") below existing levels on the adjoining beach foreshore. This is completely inappropriate in this location and in the opinion of the Directors is verging on downright dangerous.

In order to achieve the construction at this depth, excavations to a depth of 12'0"-14'0" below beach level must be created, which in the shingle sub-strata will cause considerable local disturbance. The adjoining site and bungalow to the east must be protected and maintained stable and as a consequence a substantial retaining wall would need to be constructed on the boundary, to prevent collapse of the adjoining structure. These extensive civil works will be extremely damaging adjacent to a shingle foreshore already threatened by erosion from wave action and must be considered unwise and inappropriate.

The arrangement of the basement boathouse with a ramp down from the foreshore will definitely result in basement flooding with any over-topping event on high tide and/or storm conditions. This arrangement must surely be considered a completely unsuitable proposal which could endanger adjoining properties.

For the foregoing reasons therefore the scheme as presently presented should be Refused.

#### **Appearance**

The appearance of the building is also completely inappropriate within this Area of Special Character and if allowed will create an extremely unwelcome precedent. As mentioned above, the proposal is contrary to Policy GEN7 and Area 1 of the Arun District Local Plan.

It should also be noted that the scheme proposes the installation of rooflights within the roof construction, which again is contrary to Local Plan Policies for the Beach Estate, and if allowed will create a precedent, which will undermine the Planning Authority's policies.

#### **Overlooking/overshadowing**

As a result of the considerable bulk of the building proposed it is also likely to create a serious overshadowing of the dwellings to the east, which again is unacceptable. In general the development is un-neighbourly and should be Refused by the Planning Authority.

#### **Disabled access**

The proposal makes no provision for access for people regardless of disability, age and gender. The Secretary of State has made it clear that access provisions are a Planning issue, and this has been completely ignored in the proposal.

#### **SSSI Protection**

As mentioned above the application site abuts the beach foreshore, which is part of Pagham Harbour SSSI. The Planning Authority should also note that the land to the north of East Front Road adjacent to the Application site is designated as part of Bognor Reef SSSI.

It is strongly requested that if the Planning Authority is minded to Approve the development, an Informative is included within the Decision Notice, which notifies the applicant and their contractor that there must be **NO** storage of materials upon nor disturbance of the SSSIs as a result of the construction works.

For the foregoing reasons therefore, the Company, as adjoining owner, strongly objects to the current proposal and would urge the Planning Authority to either Refuse the application, or request substantial revisions in order that the replacement building proposed fully complies with Local Plan Policies. In view of the footprint of the building proposed upon the site, it is also requested that the District Council removes Permitted Development Rights, if it is minded to Approve this application.

I would be grateful to be advised the Planning Authority's decision upon this application, when it is known.

Yours faithfully,



J.A. Higham MRICS  
Secretary

as amended 30<sup>th</sup> November 2011

cc The Clerk, Pagham Parish Council  
Chairman, Pagham Beach Residents Association  
Natural England, Regulation & Enforcement Officer – S.E. & London Region

