

**From:** Richard Castro-Parker  
**Sent:** 05 March 2019 11:52  
**To:** Planning.Responses  
**Subject:** FW: land near windmill barn, pagham road - P/94/18/PL

Please can the updated drainage comments below be uploaded to P/94/18/PL.

Thank you

Richard Castro-Parker

Senior Planning Officer (Contract)  
Arun District Council.

**From:** Laura Gibbons  
**Sent:** 05 March 2019 11:23  
**To:** Richard Castro-Parker  
**Subject:** land near windmill barn, pagham road

Hi Richard,

As discussed, I am happy to remove our request for the condition for easement to watercourse as the plans and information provided evidence that the proposed containers will not be sited within 3m of the culverted ordinary watercourse.

Thanks,

Laura Gibbons, MEng, GMICE  
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: [laura.gibbons@arun.gov.uk](mailto:laura.gibbons@arun.gov.uk)

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and [www.chichester.gov.uk](http://www.chichester.gov.uk)



Save the environment - think before you print.