

From: Amanda Scholes on behalf of Planning.Responses
Sent: 04 August 2020 11:42
To: Planning Scanning
Subject: FW: R/102/20/PL - The Spires, 6, Springfield Close, Rustington, Littlehampton, West Sussex, BN16 2SZ

Amanda Scholes | Receptionist, Department, [Arun District Council](#) | Location: Ground Floor, Arun Civic Centre, Maltravers Road, Littlehampton, BN17 5LF

Internal: 37736 | External: +44 (0) 1903 737500 ext 37736 | E-mail: amanda.scholes@arun.gov.uk



Visit Arun's web site at [Error! Hyperlink reference not valid.](#)



Save the environment - think before you print.

From: Amy Myer <Amy.Myer@arun.gov.uk>
Sent: 04 August 2020 10:53
To: Planning.Responses <Planning.Responses@arun.gov.uk>
Subject: FW: R/102/20/PL - The Spires, 6, Springfield Close, Rustington, Littlehampton, West Sussex, BN16 2SZ

Pls ensure these are added to the file and labelled as 'Environmental Health Comments'

Thanks
Amy

From: Nina Sidhu <Nina.Sidhu@arun.gov.uk>
Sent: 22 July 2020 19:09
To: Kate Giddings <kate.giddings@arun.gov.uk>
Subject: R/102/20/PL - The Spires, 6, Springfield Close, Rustington, Littlehampton, West Sussex, BN16 2SZ

Dear Amy

I am sorry my comments are late

Comments from Environmental Health

Environmental Health has no objections in principle but wishes to recommend the following conditions:

- 1) Prior to occupation of any of the dwellings, a scheme for the provision of facilities to enable the charging of electric vehicles to serve the approved dwellings shall be submitted to the local planning authority for approval and thereafter implemented in accordance with the

approved details and the charge points shall thereafter be retained and maintained in good working condition. **Reason:** New petrol and diesel cars / vans will not be sold beyond 2040, and to mitigate against any potential adverse impact of the development on local air quality, in accordance with policy QE DM3 (c) of the Arun Local Plan, the Arun District Council Electric Vehicle Infrastructure Study (November 2017) and the National Planning Policy Framework (NPPF).

- 2) No development shall take place, including any works of demolition, until a Construction Management Plan has been submitted to, and approved in writing by, the Local Planning Authority. Thereafter the approved Plan shall be implemented and adhered to throughout the entire construction period. The Plan shall provide details as appropriate but not necessarily be restricted to the following matters:-

An indicative programme for carrying out of the works;
Details of the arrangements for public engagement / consultation both prior to and continued liaison during the construction works;
Measures to minimise the noise (including vibration) generated by the construction process to include hours of work, proposed method of piling for foundations, the careful selection of plant and machinery and use of noise mitigation barrier(s);
Details of any floodlighting, including location, height, type and direction of light sources and intensity of illumination;
The parking of vehicles of site operatives and visitors;
Loading and unloading of plant and materials, including permitted times for deliveries;
Storage of plant and materials used in constructing the development;
The erection and maintenance of security hoarding including decorative displays and facilities for public viewing, where appropriate;
The provision of wheel washing facilities and other works required to mitigate the impact of construction upon the public highway (including the provision of temporary Traffic Regulations Orders);
Measures to control the emission of dust and dirt during construction;
A scheme for recycling / disposing of waste resulting from demolition and construction works i.e. no burning permitted.

Reason: To protect the amenity of local residents in accordance with Policy QE SP1 of the Adopted Arun Local Plan 2011 – 2031

- 3) No construction / demolition activities shall take place, other than between 08:00 to 18:00 hours (Monday to Friday) and 08:00 to 13:00 hours (Saturday) with no 'noisy' work on Sunday or Bank Holidays. **Reason:** To protect the amenity of local residents in accordance with Policy QE SP1 of the adopted Arun Local Plan 2011 – 2031
- 4) No external lighting shall be installed until details have been submitted to, and approved in writing by the Local Planning Authority prior to the commencement of the development. This submission shall include a layout plan with beam orientation and a schedule of light equipment proposed (luminaire type; mounting height; aiming angles and luminaire profiles). The approved scheme shall be installed, fully assessed by a competent individual when operational to ensure no light creep / bleed, maintained and operated in accordance with the approved details unless the Local Planning Authority gives its written consent to the variation. **Reason:** To protect the appearance of the area / the environment and wildlife / local residents from light pollution.
- 5) No development shall take place before a scheme has been submitted to and approved in writing by the Local Planning Authority, which specifies the provisions to be made for the control of noise emanating from plant on the site (to include ventilation, refrigeration, air

conditioning, associated ducting, fans, compressors, etc.). Thereafter, the use of the proposed development shall not commence until the approved scheme has been fully implemented. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM1 of the Adopted Arun Local Plan 2011 – 2031

- 6) Prior to commencement of the development hereby approved (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), the following components of a scheme to deal with the risks associated with contamination of the site shall each be submitted to and approved in writing by the Local Planning Authority:
1. A Preliminary Risk Assessment which has identified: all previous (historical) uses; potential contaminants associated with those uses; a conceptual model of the site indicating sources, pathways and receptors; potentially unacceptable risks arising from contamination at the site.
 2. A Site Investigation Scheme, based on (1) above to provide information for a detailed assessment of the risk to all receptors that may be affected, including those off site.
 3. Based on the Site Investigation Scheme and the detailed risk assessment (2), an options appraisal and remediation strategy giving full details of the remediation measures required and how they are to be undertaken.
 4. A Verification Report providing details of the data that will be collected in order to demonstrate that the works set out in (3) are complete and identifying any requirements for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action.

Note: Any changes to these components, (1) to (4) require the express written consent of the Local Planning Authority

The scheme shall be implemented as approved above and, prior to commencement of any construction work (or such other date or stage in development as may be agreed in writing with the Local Planning Authority), a Verification Report demonstrating completion of the works set out in the approved remediation strategy and the effectiveness of that remediation shall be submitted to and approved in writing by the Local Planning Authority. The report shall include results of sampling and monitoring carried out in accordance with the approved verification plan to demonstrate that the site remediation criteria have been met. The report shall also include a long-term monitoring and maintenance plan for longer-term monitoring of pollutant linkages, maintenance and arrangements for contingency action, as identified in the verification report, and for the reporting of this in writing to the Local Planning Authority. **Reason:** To protect the amenity of local residents in accordance with Policy QE DM4 of the Adopted Arun Local Plan 2011 – 2031

Informatives:

- The granting of this planning permission does not in any way indemnify against statutory nuisance action being taken should substantiated complaints within the remit of the Environmental Protection Act 1990 be received. For further information, please contact the Environmental Health Department on **01903 737555**.
- There shall be no burning of any trade/commercial waste or other materials on the site, except in an incinerator, the details of which shall be approved in writing by the Local

Planning Authority before the development is brought into use. The use approved shall be carried out strictly in accordance with the details agreed.

- The applicant's attention is drawn to the requirements of the Environmental Protection Act 1990 and the Clean Air Act 1993 with regard to burning on site. A statutory nuisance may be caused by smoke and/or ash from fires or noise from the cutting and/or chipping trees. In addition, air quality could be adversely affected on large projects. The granting of this planning permission does not permit a statutory nuisance to be caused. The Environment Agency should be contacted regarding Exemption Permits to burn on site.

Nina Sidhu

Senior Environmental Health Officer
Environmental Health

T: 01903 737675

E: nina.sidhu@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF

www.arun.gov.uk

Please note that I work Tuesday, Wednesday and Friday

Sign up to our newsletter [here](#)

