

From: Laura Gibbons
Sent: 04 June 2018 13:11
To: Planning.Responses
Subject: RE: Planning Consultation on R/115/18/DOC

Comments relating to Condition 6- Surface water drainage:

Based on the supplied information I recommend that condition 6 is discharged.

Regards,

Laura Gibbons, MEng, GMICE
Engineer (Drainage & Coastal)

Laura Gibbons | Engineer (Drainage & Coastal), Engineering Services, Arun District Council | Location: First Floor, Arun Civic Centre,
Maltravers Road, Littlehampton, BN17 5LF

Internal: 37818 | External: +44 (0) 1903 737818 | Fax: +44 (0) 1903 716018 | E-mail: laura.gibbons@arun.gov.uk

Arun is Working in Partnership with Chichester District Council

Visit Arun's web site at <http://www.arun.gov.uk/> and www.chichester.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 30 May 2018 17:20
To: Land Drainage
Subject: Planning Consultation on R/115/18/DOC

To: **Engineers (Drainage)**

NOTIFICATION FROM ARUN DISTRICT COUNCIL

TOWN AND COUNTRY PLANNING ACT 1990

APPLICATION R/115/18/DOC
NO:

Registered: 23-MAY-18
Site Address: 70 Woodlands Avenue Rustington BN16 3EY

Description of Works: Approval of details reserved by conditions imposed under R/65/17/PL relating to Conditions(s) 3- Full Construction Management Plan & 6- Full details of Suds Design including Drainage Layout, Construction Details, Permeable Paving Calcs & Soakaway Calcs.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 13th June 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

post_con_email
