



CEV
20 12 100

Mr Ian Jervis
The Hackwood Group Ltd
Hackwood Business Park
Water End
Basingstoke
Hampshire
RG24 7BA

Developer Services
Southern Water
Sparrowgrove House
Sparrowgrove
Otterbourne
Hampshire
SO21 2SW

Our Reference:
SWS-SUSXW-S106-011091

Date:
18/04/2018

Application to Connect to the Public Sewerage System - Section 106 Water Industry Act 1991. Location: Former Hares of Rustington, Station Road, Rustington, Littlehampton, West Sussex, BN16 3BH.

Dear Mr Jervis,

We refer to your recent application to connect to the public foul sewer at the above location. We are pleased to advise that your proposal, as shown on your drawing 505 Revision P3 Dated 06/12/2017, is approved subject to:

Please ensure connections onto the public sewer are no greater than 90 degrees and therefore against the flow.

This letter is for the purpose of approval to permit communication to be made to the public sewer, under S106 of the Water Industry Act 1991.

It is to the means and mode of construction only.

It does not give the applicant entitlement to discharge trade effluent, which will need to be processed by a separate application, as Chapter 3 of the Water Industry Act, i.e. Sections 118 et seq.

Trade effluent is any liquid waste (effluent) discharged into our sewers from a business or industrial process. This includes any waste water derived from a production process or from washing down or cooling activities including wastes from public funded activities such as municipal landfills. This can be best described as anything other than domestic sewage (toilet, bath or sink waste) or uncontaminated surface water and roof drainage (rainwater).

S106 approval does not confirm that capacity is available for the proposed development in the public sewer network. Lack of such capacity may increase the risk of flooding and

Southern Water Sparrowgrove House Otterbourne Winchester SO21 2SW www.southernwater.co.uk

Southern Water Services Ltd Registered Office: Southern House Yeoman Road Worthing BN13 3NX Registered in England No. 2366670

pollution and is a material drainage matter, for the Planning Authority to consider, by way of appropriate Planning Conditions. The availability of such capacity may be assessed through the Capacity Check process.

This letter and any comments or approvals should hence not be considered as approval by Southern Water, to the discharge of any relevant Planning Conditions, relating to drainage. This is a separate matter, to be reviewed under a consultation from the Planning Authority, to discharge any such conditions.

If connection is to be made through land under the ownership of other Parties. Then you are advised to obtain the Landowners consent before carrying out any works.

In approving this application, it is assumed that you have obtained any necessary Building Regulations Approval and /or Highway Authority Road Opening License.

This approval is given based on the information provided in support of this application and the assumption of the final discharge point being to the public foul sewer. If this is different, then this approval becomes invalid.

Southern Water will only permit the use of plastic pipes if they meet our required specification. You will need in particular to provide evidence to demonstrate that proposed plastic pipes can withstand a minimum 2600 psi jetting pressure for pipes of less than 300mm diameter.

If as noted above, there is any change in the approved connection point, then you must provide us with revised drawings and details and obtain our approval for the changes prior to the connection being made.

Construction of new manhole and arrangement of pipe junctions within the manhole should be in accordance with Sewers for Adoption 7th edition and Southern Water guidance documentation.


We refer you to Southern Water Health and Safety Advisory that can be viewed in the Developer and Builders section of the Southern Water website as the link below:

<https://www.southernwater.co.uk/health-safety-advisory>.

This approval is given on the basis that you will review this Advisory and take the necessary actions concerning Health and Safety.

Please contact Mick Vince our Assistant Project Manager for this area on 07803 259227 giving at least 2 full working days notice, in order for a mutually convenient date and time for the inspection of the works to be arranged.

Yours sincerely,



David Akenhurst
Developer Services