

From: Sue Howell
Sent: 01 October 2018 15:18
To: Planning.Responses
Cc: Anita Gardner
Subject: RE: Planning Consultation on R/152/18/DOC

Comment from Greenspace

The information submitted in dwg 15/1091/02 rev C has not been supplied in sufficient detail. The landscape planting detail needs to be included in plan form with species choice and actual proposed plant numbers, densities and height at time of planting. The drawings submitted at present are lacking this detail

I would suggest that there is insufficient information submitted and therefore **would not recommend the discharge of Landscape condition 10** imposed under consent R/52/16/PL on this application R/152/18/DOC until this information is submitted.

Sue Howell | Leisure and Landscape Officer, Greenspace, Engineering and Emergency Planning, Arun District Council | Location: Bognor Regis Town Hall, Clarence Road, Bognor Regis, West Sussex, PO21 1LD
Internal: 37943 | External: +44 (0) 1903 737943 | E-mail: sue.howell@arun.gov.uk

Visit Arun's web site at www.arun.gov.uk



Save the environment - think before you print.

From: planning.responses@arun.gov.uk [<mailto:planning.responses@arun.gov.uk>]
Sent: 13 August 2018 13:18
To: parks
Subject: Planning Consultation on R/152/18/DOC

To: Parks and Landscapes

**NOTIFICATION FROM ARUN DISTRICT COUNCIL
TOWN AND COUNTRY PLANNING ACT 1990**

APPLICATION NO: R/152/18/DOC

Registered: 09-JUL-18

Site Address: 2 Broadmark Way Rustington BN16 2EY

Description of Works: Approval of details reserved by condition imposed under R/52/16/PL relating to condition 10-landscape scheme.

The Council have received the above application to discharge conditions. I shall be pleased to receive any observations you may wish to make in respect of those conditions relating to your field of expertise.

[Click here to view the Discharge of Condition application](#)

[Click here to view conditions on original application - click on decision tab](#)

Should you have any comments to make, these should be sent by replying to this email by 27th August 2018.

www.arun.gov.uk/planning

Please be aware that any comments you may make will be available on our website so please do not insert personal details or signatures on your reply.

In the absence of a reply within the period stated, I shall assume that you have no observations to make.

The officer dealing with this application is Mrs A Gardner who can be contacted on telephone number 01903 737529.

Thanking you in anticipation

Planning Case Officer
Arun District Council

posi_con_email
