

David Easton

From: Peter Cleveland
Sent: 23 July 2010 16:06
To: Planning.Responses
Subject: FW: R/159/10

Hello

could the below email please be acknowledged as consultation response from EH to the above reference

Peter

From: Geoff Bond
Sent: 23 July 2010 16:03
To: Peter Cleveland
Subject: R/159/10

I have been asked to comment on the recent amended plans for the above restaurant and would refer to my previous comments passed to the case officer on 10 May 2010, these are:

'I have no objection to the proposed extension, which is to be constructed of appropriate materials for use in connection with the main kitchen area. I have noted the relocation of the sanitary accommodation for staff & customers, and advise that the numbers of these facilities must not be reduced in view of the anticipated increased capacity for seated customers in the dining area'.

However, the amended plan clearly illustrate a reduction to the numbers of sanitary appliances accessible to customers who are to consume food and drink at these food premises. This proposal is not in compliance with the standards adopted by this authority and in accordance with the Local Government (Miscellaneous Provisions) Act 1976, therefore, I have to object to the proposal.

Geoff Bond
Senior Food Safety Officer
Arun District Council
Tel. 01903 737675