

Copy of email from Peter Cleveland to Andy Parish of Wates. The answers to Peter's questions are highlighted in red.

From: Peter Cleveland
Sent: 30 March 2011 10:54
To: 'andy.parish@wates.co.uk'
Subject: Ref: R/287/10 58 The Street, Rustington

Dear Mr Parish

**Ref: R/287/10/ Installation of AC condenser to rear wall of store.
58 The Street, Rustington**

I write to you with reference to the above application. I have received a consultation response from Environmental Health who require some detail before considering approval of this application. Their requirements and response is as follows:

Insufficient information is available to assess the significance of noise from the a/c unit. Please confirm the following:

1. Distance from unit to the nearest noise sensitive facade.

Distance to the closest noise sensitive facade is circa 9-10m

2. Distance at which reported sound pressure level was determined.

The distance at which the sound pressure level was determined was 500mm from the AC unit. At 50db the noise emitted from the AC unit is no louder than normal conversation levels.

3. Proposed hours of operation of the a/c unit.

The AC would only be in operation during the store opening hours which are
Mon - Fri 9 - 5.30
Sat 9 - 1.00
Sun Closed

Could you please submit this detail in order for the application to proceed. If you have any questions please contact me on the number below.

Kind Regards

Peter