




From: Kate Giddings <kate.giddings@arun.gov.uk>

Sent: 22 February 2022 12:30

To: Anita Gardner <Anita.Gardner@arun.gov.uk>

Subject: RE: R/17/22/DOC - Acoustic fencing - 6 Manor Road, Rustington

Dear Anita,

I hope you're keeping well?

It is noted that the advertised 28dB reduction is under laboratory conditions, therefore results may differ slightly in the real-world situation. Furthermore and in contradiction to the written statement, a 28dB reduction is in fact less than the alleged 30dB reduction of the previous fencing option. Notwithstanding this, the submissions do technically satisfy the wording of the condition.

Many thanks,

Kate.

Kate Giddings
Senior Technical Officer
Environmental Health

T: 01903 737586
E: kate.giddings@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Road, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

Sign up to our newsletter [here](#)
Business Support during Coronavirus click [here](#)



From: Anita Gardner <Anita.Gardner@arun.gov.uk>
Sent: 16 February 2022 16:42
To: Kate Giddings <kate.giddings@arun.gov.uk>
Subject: FW: R/17/22/DOC - Acoustic fencing - 6 Manor Road, Rustington

Hi Kate,
Hope all is well with you.
I am sending this e-mail and attachments following your earlier consultation response.
Are the details now submitted acceptable?
Thanks
Anita

Anita Gardner
Principal Planner

T: 01903 737529
E: anita.gardner@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

From: Matthew Naish [REDACTED]
Sent: 16 February 2022 15:20
To: Anita Gardner <Anita.Gardner@arun.gov.uk>
Subject: Re: R/17/22/DOC - Acoustic fencing - 6 Manor Road, Rustington

CAUTION: This email originated from outside of the organisation. You should take extra care when clicking links or opening attachments - if you are unsure the content is safe contact the IT Helpdesk before clicking or opening.

Dear Anita,
Please find attached additional information from my client regarding condition 6 discharge application.
Please advise when received and if anything else is required.

Kind regards,
Matt Naish



35 Goring Road . Worthing . West Sussex . BN12 4AR



On Tue, 15 Feb 2022 at 14:19, Anita Gardner <Anita.Gardner@arun.gov.uk> wrote:

Dear Mr Naish,

The Environmental Health Officer has provided the following comments on the information submitted:

'Unable to recommend discharge of condition 6 (acoustic fencing details) because the submissions do not provide sufficient information (for example, specifying the height(s) of product to be installed, demonstrating the calculated noise reduction, the position/location of the fencing).

I would appreciate receipt of the additional details within 2 weeks of the date of this e-mail or the application will proceed to determination and is likely to be refused.

Regards

Anita Gardner

Anita Gardner

Principal Planner



T: 01903 737529

E: anita.gardner@arun.gov.uk

Arun District Council, Civic Centre, Maltravers Rd, Littlehampton, West Sussex, BN17 5LF
www.arun.gov.uk

<http://www.arun.gov.uk>

DX 57406 Littlehampton

You can view Arun District Council's Privacy Policy from <https://www.arun.gov.uk/privacy-policy>

Important Notice This e-mail is intended exclusively for the addressee and may contain information that is confidential and/or privileged. If you are not the intended recipient (or authorised to receive it for the addressee), please notify the sender and delete the e-mail immediately; using, copying, or disclosing it to anyone else, is strictly prohibited and may be unlawful. Any views, opinions or options presented are solely those of the author and do not necessarily represent those of Arun District Council. The information in this e-mail may be subject to public disclosure under the Freedom of Information Act 2000, therefore we cannot guarantee that we will not provide the whole or part of this e-mail to a third party. The Council reserves the right to monitor e-mails in accordance with relevant legislation. Whilst outgoing e-mails are checked for viruses, we cannot guarantee this e-mail is virus-free or has not been intercepted or changed and we do not accept liability for any damage caused. Any reference to "e-mail" in this disclaimer includes any attachments.
