

Iqraa Malik

From:
Sent:
To:
Cc:
Subject:

Attachments:

Importance:

Follow Up Flag: Follow up
Flag Status: Completed

Mimecast Attachment Protection has deemed this file to be safe, but always exercise caution when opening files.

This Message originated outside your organization.

Iqraa,

Thankyou for your two communication of the 29th in respect of the above with the below.

R/191/21/HH

Existing Plans

The windows on the existing front and side (south) elevations are inconsistent with the windows on the existing first floor plan. Please review and amend

Added windows on plan to front and side (south) elevation to existing 1st floor plan. 1 No. to stairs (1st floor) front and 1 No. to cupboard on south elevation (1st Floor). Both Existing and proposed plan attached with alteration. As discussed I also added the roof of the outhouse on the 1st floor plan of the existing for clarity.

Plans

The proposed south (side) elevation is inconsistent with the proposed ground and first floor plan. Please review and amend.

As per our discussion, just the first floor plan and relates to the above.

R/192/21/L

Plans

The windows on the proposed south (side) elevation are inconsistent with the proposed first floor plan. Please review and amend.

As per our discussion as above.

Plans

The proposed south (side) elevation is inconsistent with the proposed ground and first floor plan. Please review and amend.

As per our discussion as above.

Thank you for your time today clarifying this and agreeing to the attached two drawings just being resubmitted without a revision but with the windows on plan added.

