

Anita Gardner

From: Julie Grieves on behalf of Planning.Responses
Sent: 29 October 2012 17:52
To: Anita Gardner
Subject: FW: Ref R/193/12
Attachments: Pikett - 29-10-2012 A3 Elevations sheet 1 (E).pdf; Pikett - 29-10-2012 A3 Elevations sheet 2 (D).pdf

Sent: 29 October 2012 16:45
To: Planning.Responses
Subject: Ref R/193/12

For the attention of Mrs. A. Gardener

Dear Mrs. Gardener,

Please find attached revised elevation drawings for your use.

Following detailed discussions with the building control officer and fire place manufacturers it has transpired that the chimney to the rear of the property was not tall enough to draw with out the aid of a fan.

As the property is being designed and built with running cost in mind this was deemed unnecessary and we therefore have raised the chimney a little.

Hopefully this is acceptable.

Kind regards


NOTE: This email and any attachment is CONFIDENTIAL and is intended solely for the addressee. The contents may be privileged and must not be disclosed to or used by anyone other than the addressee. If you have received the message in error please destroy it and advise the sender.