



From: Nina Sidhu
Sent: 14 November 2018 16:20
To: Planning.Responses
Cc: Richard Castro-Parker
Subject: Planning Consultation on: R/212/18/PL

Response from Environmental Health

The application proposes to introduce commercial activity into an area with noise sensitive receptors in that there is residential accommodation above and adjacent to the premises. Noise from plant, machinery and ancillary activities from the proposed commercial uses may adversely impact the amenity of existing occupiers in the area. No information on noise exposure is provided within the application and therefore it is considered that the application contains insufficient detail to be properly determined. In order to ensure any adverse noise impacts are appropriately mitigated, a noise impact assessment is required which characterises the prevailing noise environment and identifies any potentially significant sources of noise. I therefore recommend refusal.